

Cooling Tower Microorganism Controller

ACCEPTED

MAY 14 1981

Under the Federal Insecticide, Fungicide, and Rodenticide Act as amended, for the pesticide registered under EPA Reg. No. 8123-90

ACTIVE INGREDIENT:

Potassium dimethyldithiocarbamate 16.6%

INERT INGREDIENTS 83.4%

This product contains 1.48 lb. of active ingredient per gallon and weighs 8.93 lb. per gallon.

WARNING

KEEP OUT OF REACH OF CHILDREN

PRECAUTIONARY STATEMENTS

HAZARDS TO HUMANS AND DOMESTIC ANIMALS

WARNING: Causes eye damage and skin irritation. Harmful if swallowed. Do not get in eyes, on skin, or on clothing. Avoid contamination of food. Wear goggles or face shield and rubber gloves when handling. Wash thoroughly after handling.

STATEMENT OF PRACTICAL TREATMENT: *In case of skin contact*, wash with plenty of soap and water. Remove contaminated clothing and wash before reuse. *If product gets in the eyes*, flush immediately with copious amounts of clean, cool water for at least 15 minutes. Get medical attention immediately. *If product is swallowed*, call a physician immediately. If patient is conscious, induce vomiting by stroking or tickling the patient's throat or far back on patient's tongue. Emetics such as 2 teaspoonsful (10 mL) of ipecac syrup or 1 teaspoonful (5 mL) of dry mustard in warm water to form a paste or even soap in warm water can be used. Repeat until vomit fluid is clear. Then have patient drink plenty of milk, gelatin solution, beaten egg whites, flour and water, or other nonoily demulcent. *Never induce vomiting or give anything by mouth to an unconscious person.*

Note to physician: Probable mucosal damage may contraindicate gastric lavage.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Do not discharge into lakes, streams, ponds, or public waters unless in accordance with an NPDES permit. For guidance contact your Regional Office of the EPA.

DIRECTIONS FOR USE GENERAL CLASSIFICATION:

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

Cooling Tower Microorganism Controller is used in cooling water systems and industrial air-washing systems to control microbiological slime. In cooling systems, add 3.4 to 10.3 fl. oz. of Cooling Tower Microorganism Controller per 1000 gal. of water to the cooling tower sump. In air-washing systems, add 12 to 20.5 fl. oz. of Cooling Tower Microorganism Controller per 1000 gal. of water to water-collection trays. Repeat treatments every 1-5 days, or as needed. The required frequency depends on relative amount of bleed and severity of slime problem.

STORAGE AND DISPOSAL

PROHIBITIONS: Do not contaminate water, food, or feed by storage or disposal. Open dumping is prohibited.

PESTICIDE DISPOSAL: Pesticide, spray mixture, or rinsate that cannot be used or chemically reprocessed should be disposed of in a landfill approved for pesticides, or buried in a safe place away from water supplies.

CONTAINER DISPOSAL:

METAL: Triple rinse (or equivalent) and offer for recycling, reconditioning, or disposal in an approved landfill or bury in a safe place. Containers over 30 gallons should be resealed before offering for reconditioning.

PLASTIC: Containers under 30 gallons must not be reused but should be triple rinsed and disposed of in an incinerator or landfill approved for pesticide containers or buried in a safe place. Containers over 30 gallons are to be resealed and offered for reconditioning or triple rinsed (or equivalent) and offered for recycling, reconditioning, or disposal in an approved landfill or buried in a safe place.

GENERAL: Consult Federal, State, or Local disposal authorities for approved alternative procedures.

Manufactured by:

Frank Miller & Sons, Inc.
13831 South Emerald Avenue
Chicago, IL 60627

22

EPA REG. NO. 8123-90

EPA EST. NO. _____

NET CONTENTS _____