


GARRATT-CALLAHAN CO.
WATER TREATMENT ENGINEERS SINCE 1904

OFFICES IN PRINCIPAL
CITIES AND STRATEGIC
INDUSTRIAL AREAS



HOME OFFICE
111 ROLLINS RD.
MILLBRAE
CALIFORNIA 94030

FORMULA NO. 30-A

TO AID IN THE CONTROL OF ALGAL AND BACTERIAL SLIMES IN INDUSTRIAL
RECIRCULATING COOLING WATER SYSTEMS

U.S.D.A. REGISTRATION NUMBER 8540-3

ACTIVE INGREDIENTS

Alkyl (50% C₁₄, 40% C₁₂, 10% C₁₆) dimethyl benzyl ammonium chlorides..... 7%

INERT INGREDIENTS..... 93%

INSTRUCTIONS

Biocides are most effective against microorganisms if the system to be treated is first cleaned of as much deposit and debris as possible. Formula 30-A may be added directly to the water being treated. Addition may be made in the basin or sump of a cooling tower or over the surface of a cooling pond. A slug dose of 1 to 2 pints of Formula 30-A per 1,000 gallons of water is an average treatment. This is the equivalent of 125 to 250 ppm of Formula 30-A. This dose may be repeated every seven days or less until biological control is effected. Dosages may require adjustment to meet specific needs. Consult your Garratt-Callahan Engineer.


CAUTION

Harmful if swallowed. Do not allow to get in eyes. In case of contact with skin or eyes, flush with water and get medical attention. It is suggested that protective clothing and goggles be worn when handling. This is not a foodstuff and should not come in contact with food or potable water.

CAUTION

FOR INDUSTRIAL USE ONLY

KEEP OUT OF THE REACH OF CHILDREN



8540-3

8540-3

5/28/1969

page 1 of 1