




GARRATT-CALLAHAN CO.
WATER TREATMENT ENGINEERS SINCE 1904

OFFICES IN PRINCIPAL
CITIES AND STRATEGIC
INDUSTRIAL AREAS



HOME OFFICE
111 ROLLINS RD.
MILLBRAE
CALIFORNIA 94030

FORMULA NO. 30-A

TO AID IN THE CONTROL OF ALGAL AND BACTERIAL SLIMES IN INDUSTRIAL
RECIRCULATING COOLING WATER SYSTEMS

U.S.D.A. REGISTRATION NUMBER 8540-3

ACTIVE INGREDIENTS

Alkyl (50% C₁₂, 40% C₁₃, 10% C₁₄) dimethyl benzyl ammonium chlorides..... 7%

INERT INGREDIENTS..... 93%

INSTRUCTIONS

Biocides are most effective against microorganisms if the system to be treated is first cleaned of as much deposit and debris as possible. Formula 30-A may be added directly to the water being treated. Addition may be made in the basin or sump of a cooling tower or over the surface of a cooling pond. A slug dose of 1 to 2 pints of Formula 30-A per 1,000 gallons of water is an average treatment. This is the equivalent of 125 to 250 ppm of Formula 30-A. This dose may be repeated every seven days or less until biological control is effected. Dosages may require adjustment to meet specific needs. Consult your Garratt-Callahan Engineer.

Danger *to prevent eye, skin contact.*

Corrosive to Eyes. Causes eye damage and skin irritation. Do not get in eyes, on skin or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful if swallowed. Avoid contamination of food.


In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician.

FOR INDUSTRIAL USE ONLY

KEEP OUT OF THE REACH OF CHILDREN

GC 500

NOTE: Statement of net weight is stencilled on container.



8540-3

1/17/1972

Page 121