



Main Office: 50 Ingold Road, Burlingame, CA 94010 (650) 697-5811 FAX (650) 692-6098

Plants: Addison, IL Atlanta, GA Edison, NJ Dallas, TX Burlingame, CA

www.g-c.com

**PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND DOMESTIC ANIMALS**

CAUTION

Harmful if swallowed. Avoid contact with skin, eyes or clothing. Wash thoroughly with soap and water after handling.

ENVIRONMENTAL HAZARDS

This product is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance, contact your State Water Board or Regional Office of the EPA.

STORAGE AND DISPOSAL


Do not contaminate water, food, or feed by storage or disposal.

STORAGE: Do not expose to extreme temperatures. Do not stack more than four drums high. Drums should be opened in well-ventilated areas. Leaking or damaged drums should be placed in overpack drums for disposal. Spills should be absorbed in sawdust or sand and disposed of in a sanitary landfill. Keep containers closed when not in use.

PESTICIDE DISPOSAL: Pesticide wastes are toxic. Improper disposal of excess pesticide, spray mixture, or rinsate is a violation of Federal Law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste representative at the nearest EPA Regional Office for guidance.

CONTAINER DISPOSAL:

Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, by incineration, or, if allowed by State and local authorities, by burning. If burned, stay out of smoke.



PRODUCT NO. 0297044
NET WEIGHT 40 LBS. (4.6 G)

FORMULA 32

TO AID IN THE CONTROL OF ALGAL AND BACTERIAL SLIMES
IN INDUSTRIAL RECIRCULATING COOLING WATER SYSTEMS

ACTIVE INGREDIENT:

POLY(OXYETHYLENE(DIMETHYL- IMINIO)ETHYLENE(DIMETHYL- IMINIO)-ETHYLENE DICHLORIDE	18.0%
INERT INGREDIENTS:	82.0%
TOTAL	100.0%

**KEEP OUT OF REACH OF CHILDREN
CAUTION**

FIRST AID

IF IN EYES	<ul style="list-style-type: none"> Hold eye open and rinse slowly and gently with water for 15 - 20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control center or doctor for treatment advice.
IF ON SKIN OR CLOTHING	<ul style="list-style-type: none"> Take off contaminated clothing. Rinse skin immediately with plenty of water for 15 - 20 minutes. Call a poison control center or doctor for treatment advice.
IF SWALLOWED	<ul style="list-style-type: none"> Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by the poison control center or doctor. Do not give anything by mouth to an unconscious person.
IF INHALED	<ul style="list-style-type: none"> Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control center or doctor for further treatment advice.

HOT LINE NUMBER

You may contact the Poison Center at 1-800-222-1222 for emergency medical treatment information.

Have the product container or label with you when calling a poison control center or doctor, or going for treatment. You may also call 1-303-623-5716 day or night for emergency medical treatment information.


See Side Panel For Additional Precautionary Statements

DIRECTIONS FOR USE

GENERAL CLASSIFICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

Formula 32 is used to control algae, bacteria, and fungus in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 3.3 to 8.2 fluid ounces of Formula 32 per 1000 gallons of water, to provide a concentration of 27 to 66ppm of Formula 32 based on the total weight of water in the system is recommended. Subsequent slug additions of 0.82-8.2 fluid ounces of Formula 32 per 1000 gallons of water (6.6 to 66ppm of Formula 32) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.



EPA REG. NO. 8540-8

EPA EST. NO. 8540-CA-1

8540-TX-1

8540-GA-1

8540-IL-1

8540-NJ-1

MANUFACTURED BY GARRATT-CALLAHAN COMPANY

REV. 05/2005

MADE IN USA

8540-8

03/22/2006