

MITCO CC-11-L ALGICIDE

FOR CONTROLLING GROWTH OF ALGAE IN INDUSTRIAL RECIRCULATING WATER COOLING SYSTEMS

ACTIVE INGREDIENTS

N-Alkyl (C₁₄, C₁₂, C₁₆) dimethyl
benzyl ammonium chlorides
Bis (tri-n-butyltin) oxide

INERT INGREDIENTS

Water
Butoxypolyoxypropylene-
polyoxyethylene Glycol
Sodium Hydroxide
Total Inert Ingredients — 92%

U.S.D.A. Reg. No. 8637-5

KEEP OUT OF REACH OF CHILDREN

CAUTION

Harmful if swallowed. May be absorbed through skin. Causes skin irritation. Avoid breathing spray mist. Avoid contact with skin, eyes or clothing. In case of contact immediately remove contaminated clothing and wash skin with soap and water; for eyes, flush with plenty of water and get medical attention. Wash clothing before reuse. Avoid storage near food and food products.

This product is toxic to fish. Do not dispose or treat effluent directly into flowing water.

DIRECTIONS FOR USE

This product is intended to be fed intermittently into the system. Chemical may be poured into the sump of the cooling tower or evaporative condenser. The system should be cleaned before application of an initial dose of 5 to 10 gallons of CC-11-L to 10,000 gallons of water. Subsequently a dosage of 2 to 5 gallons of CC-11-L per 10,000 gallons of water should be added. Chemical addition should be made weekly during the season when algae are likely to develop. When treating system for the first time, add chemical in small increments to determine the extent of foaming. Your Mitco service engineer can furnish detailed instructions.

DISTRIBUTED BY

Mitco INC.

1601 Steele Avenue, S.W. Grand Rapids, Michigan 49502

Net contents shown elsewhere on container.

MITCO CC-11-L ALGICIDE

FOR CONTROLLING GROWTH OF ALGAE IN INDUSTRIAL RECIRCULATING WATER COOLING SYSTEMS

ACTIVE INGREDIENTS

N-Allyl (C₁₂H₂₅Cl) Chloride
Benzyl ammonium chloride
Isotri-n-butyltin oxide

INERT INGREDIENTS

Water
Butoxy polyoxypropylene
polyoxyethylene Glycol
Sodium Hydroxide
Total Inert Ingredients 92%

U.S.D.A. Reg. No. 8637-5

KEEP OUT OF REACH OF CHILDREN

CAUTION

DIRECTIONS FOR USE

This product is intended to be fed intermittently into the systems of recirculating water cooled into the sump of the cooling tower or evaporator condenser. The system should be cleaned before application of an initial dose of 5 to 10 gallons of CC-11-L per 10,000 gallons of water. Subsequently a dosage of 2 to 5 gallons of CC-11-L per 10,000 gallons of water should be added. Chemical addition should be made weekly during the season when algae are likely to develop. When treating systems for the first time, add chemical in small increments to determine the correct dosage rate. Your Mitsui Sales Representative can furnish detailed instructions.

Mitsui INC.

Net contents shown elsewhere on container