

MITCO CC-12-L ALGICIDE

FOR CONTROLLING GROWTH OF ALGAE IN INDUSTRIAL RECIRCULATING WATER COOLING SYSTEMS

COMPOSITION

	Percent by weight
Active ingredient	10.0 percent
Poly [oxyethylene (dimethyliminio) ethylene (dimethyliminio) — ethylene dichloride]	10.0 percent
Inert ingredient	90.0 percent
Weight per gallon	8.5 pounds
Weight of active ingredient per gallon ..	0.85 pound

EPA Reg. No. 8637-7

APPLICATION

Mitco CC-12-L Algicide is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 6 to 15 fluid ounces of Mitco CC-12-L Algicide per 1000 gallons of water, to provide a concentration of 48 to 120 parts per million of Mitco CC-12-L Algicide based on the total weight of water in the system is recommended. Subsequent slug additions of 1.5 to 15 fluid ounces of Mitco CC-12-L Algicide per 1000 gallons of water (12 to 120 parts per million of Mitco CC-12-L Algicide) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

CAUTION

KEEP OUT OF THE REACH OF CHILDREN

Harmful if swallowed, inhaled, or absorbed through skin. Avoid contact with skin and eyes. In case of contact, flush with plenty of water for at least 15 minutes. If irritation persists, get medical attention. Avoid contamination of food. Do not reuse empty drum. Return to drum record holder or destroy by perforating or crushing and burying in a safe place.

This product is toxic to fish. Do not add treated effluent to lakes, streams or ponds. Do not contaminate water by cleaning of equipment or disposal of waste. Use only at approved locations.

DISTRIBUTED BY

Mitco INC.

ALL INFORMATION IS SUBJECT TO CHANGE WITHOUT NOTICE

Net contents shown elsewhere on container

MITCO CC-12-L ALGICIDE

FOR CONTROLLING GROWTH OF ALGAE IN INDUSTRIAL RECIRCULATING WATER COOLING SYSTEMS

COMPOSITION

	Percent by weight
Active ingredient	10.0 percent
Polyoxyethylene (20 methyl) nonyl ether (ethylene oxide) ethylene dichloride	10.0 percent
Inert ingredient	79.0 percent
Weight per gallon (128 fluid ounces)	8.5 pound
Weight of active ingredient per gallon	0.85 pound

EPA Reg. No. 8637-7

APPLICATION

Mitco CC-12-L Algicide is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 6 to 15 fluid ounces of Mitco CC-12-L Algicide per 1000 gallons of water, to provide a concentration of 48 to 120 parts per million of Mitco CC-12-L Algicide based on the total weight of water in the system is recommended. Subsequent slug additions of 1.5 to 15 fluid ounces of Mitco CC-12-L Algicide per 1000 gallons of water (12 to 120 parts per million of Mitco CC-12-L Algicide) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the main of water cooling towers.

CAUTION

KEEP OUT OF THE REACH OF CHILDREN

Mitco Inc.