MITCO CC-20-L ALGICIDE

FOR CONTROLLING GROWTH OF ALGAE IN INDUSTRIAL
RECIRCULATING WATER COOLING SYSTEMS

EPA Reg. No. 8637-12

SPECIFICATIONS

Mitco Inc.

MITCO CC-20-L ALGICIDE

FOR CONTROLLING GROWTH OF ALGAE IN INDUSTRIAL RECIRCULATING WATER COOLING SYSTEMS

[illegible]

Dissolved [illegible]	[illegible]
Potassium [illegible]	[illegible]

[illegible]

Weight [illegible]	10.2 pounds
Weight of active ingredients per gallon	.57 pounds

EPA Reg. No. 8637-12

APPLICATIONS

MITCO CC-20-L ALGICIDE is used to inhabit the growth of algae, bacteria, and fungi in recirculating commercial and industrial cooling water systems. Before treatment with CC-20-L systems must be cleaned to remove algal growth, microbiological slime, and other deposits. Then the system should be treated with an initial slug addition of 1.5 to 3.0 fluid ounces of CC-20-L per 1,000 gallons of water in the system. Repeat the initial dosage until control is evident. Subsequent slug additions of 0.5 to 3.0 fluid fluid ounces of CC-20-L per 1,000 gallons of water should be made 1 to 5 days or as needed. The required frequency of treatment depends on the relative amount of bleedoff and the severity of the microbiological problem. Slug additions of CC-20-L should be made to the sump of water cooling towers.

WARNING

KEEP OUT OF THE REACH OF CHILDREN

[illegible]

Mitco INC.

[illegible]

Net contents shown elsewhere on container.

ACCEPTED

MAY [illegible] 1975

[illegible]

ACCEPTED WITH COMMENTS