949594-9

### DENTICIDE TRECTION

is used to control algae, bacteria and fungilating commercial and industrial water cooling rior to its use, systems must be cleaned to Igal growth, microbiological slime and other An initial slug addition of 13 to 35 fluid ICC W-62 per 1000 gallons of water to procentration of 100 to 250 parts per million of based on the total weight of water in the recommended. Repeat initial dosage until evident. Subsequent slug additions of 3.5 to

ounces of ICC W-62 per 1000 gallons of water 50 parts per million of ICC W-62) should be

every 2 to 5 days or as needed. The freaddition depends upon the relative amount

off and the severity of the microbiological Slug additions should be made in the sump of

ing towers.

## **ICC W-62**

#### FOR ALGAE CONTROL IN COOLING TOWERS

#### **ACTIVE INGREDIENT:**

Poly [oxyethylene (dimethyliminio) ethylene	
(dimethyliminio) ethylene dichloride]	4.8%
INERT INGREDIENT	95.2%
1	00.0%

### CAUTION

#### KEEP OUT OF REACH OF CHILDREN

See additional cautions on right side panel

Net . . . . . Galions

**EPA REG. NO.: 9594-9** 

#### CAUTION

Harmful if swallowed. Do not get in eyes. Avoid contact with skin. In case of contact, flush with plenty of water for at least 15 minutes. If eye irritation persists, get medical attention. Avoid contamination of food.

Rinse empty container thoroughly with water and discard container.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Apply ICC W-62 only as specified on this label. Do not contaminate water by cleaning of equipment or disposal of waste.

AUTION A Commence of the Commence of 

# INTERCONTINEN AL CHEMICA URPORATION

MANUFACTURING PLA 1 SACRAMENTO, CAL OFFICE

**)**(...)

WAREHOUSE

CINCINNA ANAHEIM .....

RINCIPAL