

GC SUPER 50 will control algae and bacterial slimes found in recirculating cooling tower waters. **GC SUPER 50** helps clean and loosen slime debris from cooling system surfaces. When used in slug doses, no other microbicide is required.

GC SUPER 50 is economical to use because it is concentrated. It should be handled with care.

DANGER:

Keep Out of Reach of Children. Corrosive. Causes severe eye and skin damage. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

FIRST AID:

In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash contaminated clothing before reuse.

If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

NOTE TO PHYSICIAN: Probable mucosal damage may contraindicate the use of gastric lavage. Measures against circulatory shock, respiratory depression, and convulsion may be needed.

GC SUPER 50

Twin-Chain Quaternary
Ammonium Compound Concentrate

Water Treatment Microbicide
for Building and Industrial Cooling Towers

Active Ingredients

Didecyl dimethyl ammonium chloride 50%
Isopropyl alcohol 20%

Inert Ingredients

30%
100%

EPA Registration No. 6836-32-9619

EPA Establishment No. 9619-Ma-1

Net Weight 400 lbs.

Net Volume 55 gals.

Sold by
SYNTHETIC LABS. INC.
P.O. Box 131, Braintree, MA 01826

DANGER:

KEEP OUT OF REACH OF CHILDREN. SEE LEFT
PANEL FOR ADDITIONAL PRECAUTIONARY STATEMENTS

ACCEPTED

03 March 1980

9619-2

USE DIRECTIONS

To control algae and bacterial slimes, use **GC SUPER 50** as directed. For best results, slug feed. The addition of microbicide needed depends on factors. To optimize your use of **GC SUPER 50**, follow the procedure:

1. Initially use 6 fluid ounces per 1000 gallons of water to be treated (20 ppm active quaternary). Should the above dosage not give satisfactory results, use 9 fluid ounces per 1000 gallons. Repeat the initial dose every seven days or more frequently if needed.

2. When the above treatment level is successful, use 3 fluid ounces per 1000 gallons of water. Repeat weekly as needed. Should slime develop again, go back to step 1.

Cooling tower waters that are inherently high in bacteria count may be adequately controlled by the lower range of these dosages; slug feed every 7-10 days.

Dilute the appropriate amount of **GC SUPER 50** in 100 gallons of water then add to the sump of the cooling tower. This product weighs 7.45 lbs. per gallon.

This product is toxic to fish. Treatment effluent should be discharged where it will drain into a sewer, pond, or public water.

Should tower be heavily fouled, a precleaning procedure should be used.

Do not reuse empty drum. Return to drum manufacturer. Rinse well with soap solution and discharge to sanitary water by disposal of waste.

BEST DOCUMENT AVAILABLE

GC SUPER 50

Twin-Chain Quaternary
Ammonium Compound Concentrate

Water Treatment Microbiocide
for Building and Industrial Cooling Towers

Active Ingredients

Didecyl dimethyl ammonium chloride 50%
Isopropyl alcohol 20%

Inert Ingredients

30%
100%

EPA Registration No. 6836-32-9619

EPA Establishment No. 9619-Ma-1

Net Weight 400 lbs.

Net Volume 55 gals

Sold by
SYNTHETIC LABS, INC.
P.O. Box 131, Dracut, MA 01826

DANGER:

KEEP OUT OF REACH OF CHILDREN. SEE LEFT
PANEL FOR ADDITIONAL PRECAUTIONARY STATE-
MENTS.

ACCEPTED
03 MAR 1980
EX-9-9

USE DIRECTIONS

For algae and bacterial slimes use **GC SUPER 50** as directed. For best results, slug feed. The frequency of addition of microbiocide needed depends on many factors. To optimize your use of **GC SUPER 50**, follow this procedure:

1. Initially use 6 fluid ounces per 1000 gallons of water to be treated (20 ppm active quaternary). Should the above dosage not give satisfactory results, use 9 fluid ounces per 1000 gallons of water. Repeat the initial dose every seven days or increase the frequency if needed.
2. When the above treatment level is successful, use 2 to 3 fluid ounces per 1000 gallons of water to maximize efficiency. Repeat weekly as needed. Should slime develop again, go back to initial dosage.

Cooling tower waters that are inherently low in algae growth and bacteria count may be adequately controlled by the lower range of these dosages, slug fed every seven days.

Dilute the appropriate amount of **GC SUPER 50** in 1 or 2 gallons of water then add to the sump of the tower. Note: this product weighs 7.45 lbs. per gallon (at 20°C).

This product is toxic to fish. Treatment effluent should not be discharged where it will drain into lakes, streams, ponds or public water.

Should tower be heavily fouled, a pre-cleaning is required.

Do not reuse empty drum. Return to drum conditioner or rinse well with soap solution and discard. Do not contaminate water by disposal of waste.

SP-507-11

BEST DOCUMENT AVAILABLE