

CWT-BB11

INHIBITS ALGAE, FUNGI, AND BACTERIAL SLIME IN RECIRCULATING COOLING TOWERS & EVAPORATIVE CONDENSERS

CONTENTS: 30 U.S. GALLONS

WARNING: KEEP OUT OF REACH OF CHILDREN

Causes eye damage and skin irritation. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

FIRST AID: In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes call a physician. Remove and wash contaminated clothing before reuse.

If swallowed, give patient doses of powdered charcoal immediately or all he can swallow of raw egg whites, milk, gruel, or flour and water. Then induce vomiting with salt, soap, or mustard in warm water. Call a physician immediately.

Do not reuse empty drum. Return to drum reconditioner or destroy by perforating or crushing and burying in a safe place.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Do not contaminate water by cleaning of equipment, or disposal of wastes. Apply this product only as specified on this label.

DIRECTIONS FOR USE: CWT-BB11 is placed in the sump of the recirculating water cooling tower. Before using, clean strainers and remove spray nozzle restrictions. Clean the rest of the system thoroughly by mechanical means or with Acid Cleaner H or Acid Cleaner S to remove algal growth, microbiological slime and other deposits. When dosage is determined, run the circulating pump for 24 hours or longer with regular bleed. Then drain and flush out all organic material. Faster results can be achieved if it is possible to close the bleed valve for a period of time.

DOSAGE: An initial slug of 5.1 to 10.2 fluid ounces is recommended per 1,000 gallons of water in the system. This should be repeated as often as necessary until control is evident. Subsequent slug additions of 1.7 to 10.2 fluid ounces should be made every 1 to 5 days or as needed. The frequency is dependent upon bleedoff rate and the severity of the microbiological problem.

If water content is not known, use the following chart as an approximation of dosage, repeating until control is achieved.

| CAPACITY IN TONS | INITIAL SLUG (Fl. Oz.) | SUBSEQUENT SLUGS (Fl. Oz.) |
|------------------|------------------------|----------------------------|
| 10 | 3 to 6 | 1 to 6 |
| 25 | 7.5 to 15 | 2.5 to 15 |
| 50 | 15 to 30 | 5 to 30 |
| 100 | 30 to 60 | 10 to 60 |

Active ingredients:

Disodium cyanodithioimidocarbonate

Ethylene diamine

Potassium N-methylthiocarbamate

Inert ingredients:

11.65 percent

1.73 percent

1.60 percent

5.83 percent

88.34 percent

100.00 percent

E.P.A. Reg. No. 9200-10

E.P.A. Est. 9800 NY 1

Made in U.S.A.

STEWART HALL
CHEMICAL CORPORATION
MOUNT VERNON, NEW YORK 10553

Local Distributor:

CW-T-BBII

INHIBITS ALGAE, FUNGI, AND BACTERIAL
SLIME IN RECIRCULATING COOLING
TOWERS & EVAPORATIVE CONDENSERS

CONTENTS: 30 U.S. GALLONS

WARNING: KEEP OUT OF REACH OF CHILDREN

Causes eye damage and skin irritation. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if swallowed. Avoid inhalation of fumes.

FIRST AID: In case of contact, or if swallowed, give patient doses of raw egg whites, milk, gruel or flour and water.

Do not reuse empty drum. Return to original container.

This product is for industrial use only. Do not use in residential areas. Do not discharge into streams, ponds or other bodies of water.

DIRECTIONS FOR USE: CW-T-BBII is used in recirculating water cooling towers. Before using, clean the system thoroughly by mechanical means to remove algal growth, microorganisms and other deposits. Then drain and flush out the system. Add CW-T-BBII to the water.

DOSAGE: An initial slug of 1 to 10 ounces per gallon of water in the system. This should be followed by subsequent slugs of 1 to 2 ounces per gallon as needed. The frequency is dependent on the water content of the system.

| CAPACITY IN TONS | INITIAL SLUG (FL. OZ.) | SUBSEQUENT SLUGS (FL. OZ.) |
|------------------|------------------------|----------------------------|
| 10 | 5 to 6 | 1 to 6 |
| 25 | 7.5 to 15 | 2.5 to 15 |
| 50 | 15 to 30 | 5 to 30 |
| 100 | 30 to 60 | 10 to 60 |

Active Ingredients:
Chlorine
Hydrochloric Acid
Hydroxyethylamine
Sodium N-methylglucamine
Sodium Hydroxide

© P.A. Inc., The System

Do not get in eyes, on skin, or on clothing. Wear goggles when handling. Harmful or fatal if swallowed. Avoid inhalation of fumes.

FIRST AID: Immediately flush eyes or skin with plenty of water for at least 15 minutes. If eyes call for medical attention, call a physician. Remove and wash contaminated clothing before reuse.

If powdered charcoal immediately or at the first swallow of water. Then induce vomiting with salt, soap, or mustard. Call a physician immediately.

Do not recondition or destroy by perforating or crushing in a safe place.

Effluent should not be discharged where it will drain into water. Do not contaminate water by cleaning of equipment with this product unless specified on this label.

placed in the supply of the recirculating water cooling tower. Before using, clean the system thoroughly by mechanical means with Acid Cleaner II or Acid Flasher S to remove algal growth, microorganisms and other deposits. When dosage is determined, or once with regular bleed. Then drain and flush out the system. Add CW-T-BBII to the water. If possible, use the bleed valve or a period of time.

2 fluid ounces is recommended per 1,000 gallons of water. This should be repeated as often as necessary into control is evident. 0.2 fluid ounces should be made every 1 to 3 days or until a minimum bleedoff rate and the severity of the microbiological problem.

| CAPACITY IN TONS | INITIAL SLUG (FL. OZ.) | SUBSEQUENT SLUGS (FL. OZ.) |
|------------------|------------------------|----------------------------|
| 10 | 5 to 6 | 1 to 6 |
| 25 | 7.5 to 15 | 2.5 to 15 |
| 50 | 15 to 30 | 5 to 30 |
| 100 | 30 to 60 | 10 to 60 |

Active Ingredients:
Chlorine
Hydrochloric Acid
Hydroxyethylamine
Sodium N-methylglucamine
Sodium Hydroxide

© P.A. Inc., The System

STEWART HALL
CHEMICAL CORPORATION
MOUNT VERNON, NEW YORK 10553

Local Distributors

WARNING: KEEP OUT OF REACH OF CHILDREN

Causes eye damage and skin irritation. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

FIRST AID: In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes call a physician. Remove and wash contaminated clothing before reuse.

If swallowed, give patient doses of powdered charcoal immediately or all he can swallow of raw egg whites, milk, gruel, or flour and water. Then induce vomiting with salt, soap, or mustard in warm water. Call a physician immediately.

Do not reuse empty drum. Return to drum conditioner or destroy by perforating or crushing and burying in a safe place.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Do not contaminate water by cleaning of equipment, or disposal of wastes. Apply this product only as specified on this label.

DIRECTIONS FOR USE: CWT-BB11 is placed in the sump of the recirculating water cooling tower. Before using, clean strainers and remove spray nozzle restrictions. Clean the rest of the system thoroughly by mechanical means or with Acid Cleaner H or Acid Cleaner S to remove algal growth, microbiological slime and other deposits. When dosage is determined, run the circulating pump for 24 hours or longer with regular bleed. Then drain and flush out all organic material. Faster results can be achieved if it is possible to close the bleed valve for a period of time.

DOSAGE: An initial slug of 5.1 to 10.2 fluid ounces is recommended per 1,000 gallons of water in the system. This should be repeated as often as necessary until control is evident. Subsequent slug additions of 1.7 to 10.2 fluid ounces should be made every 1 to 5 days or as needed. The frequency is dependent upon bleedoff rate and the severity of the microbiological problem.

If water content is not known, use the following chart as an approximation of dosage, repeating until control is achieved:

| CAPACITY IN TONS | INITIAL SLUG (Fl. Oz.) | SUBSEQUENT SLUGS (Fl. Oz.) |
|------------------|------------------------|----------------------------|
| 10 | 3 to 6 | 1 to 6 |
| 25 | 7.5 to 15 | 2.5 to 15 |
| 50 | 15 to 30 | 5 to 30 |
| 100 | 30 to 60 | 10 to 60 |

| | |
|------------------------------------|----------------|
| Active ingredients | 11.66 percent |
| Disodium cyanodithioimidocarbonate | 4.23 percent |
| Ethylenediamine | 1.60 percent |
| Potassium N-methyldithiocarbamate | 5.83 percent |
| Inert ingredients | 88.34 percent |
| | 100.00 percent |

E.P.A. Reg. No. 9800-10

E.P.A. Est. 9800-NY-1

Made in U.S.A.

STEWART HALL ACCEPTED
CHEMICAL CORPORATION
 MOUNT VERNON, NEW YORK 10553
 MAR 12 1976

Local Distributor:

ACCEPTED WITH COMMENTS