

... ethically applied

SPECIALTY PRODUCT

TSC-902

ALGAECIDE

UIRECTIONS:

"Aqua-Tech" TSC-902 is used for the control of fungi and algae in cooling towers and open spray systems. Badly fouled systems must be cleaned before treatment is begun. Determine total water capacity in system to be treated and allow 1 oz. Aqua-Tech TSC-902 100 gallons initially at threeday intervals until control of growths present is evident. Subsequently, slug feed at two-week intervals or oftener if necessary to prevent regrowth, one-half

is dosage. This product should placed in the basin at a point where rapid circulation occurs. Control of growths present will usually be evident within 24 hrs. Normal bleed-off rates will result in gradual dilution of treatment, therefore it is desirable to bleed the system heavily just prior to dosing. Then halt cleed-off completely for 12 to 24 hrs. See product bulletin for Sidicional details.

COMPOSITION:

ACTIVE INGREDIENTS: Sodium pentachlorophenate .	90% 79%
Sodium salts of other chlorophenols	
INERT INGREDIENT:	10%
NET CONTENTS:	lbs
WARNING	

WARNING: KEEP OUT OF THE REACH OF CHILDREN.

This product is a metabolic stimulant and causes hyperthermia. Treat symptomatically.

See side panel at right for additional warnings. EPA Est. No. 9861-Ga-1 EPA Reg. No. 9861-2



SPECIALTY PRODUCT

TSC-902

WARNING:

KEEP OUT OF THE REACH OF CHILDREN. Harmful if swallowed. Do not take internally. Do not breathe dust or get in eyes or on clothing. In case of skin contact with dry material or its solution, wash with soap and water thoroughly. After eye contact, flush with plenty of water and get medical attention. If swallowed, induce vomiting and call a physician. Wash clothing before reuse.

This product is toxic to fish and wildlife. Treated effluent should not be discharged where it will drain into lakes, streams or ponds.

Keep container closed when not in use.

> When empty, destroy container and discard in a safe place. DO NOT REUSE CONTAINER.

TECHNICAL SPECIALTIES CORPORATION Serving The Nearl Of Diale 114 South Columbia Drive / Decatur, Georgia 30030 Telephone (404) 378-1403

Nov 6, 1974

•

9861-2

