### PRECAUTIONARY STATEMENTS HAZAROS TO HUMANS AND DOMESTIC ANIMALS

**CAUTION:** Harmful if swallowed. Avoid breathing vapors. Do not get in eyes or on skin or clothing. Avoid contamination of food.

#### STATEMENT OF PRACTICAL TREATMENT

IF IN EYES: Flush eyes and under eyelids with plenty of water for at least 15 minutes. Call a physician immediately.

IF ON SKIN: Remove contaminated clothing and launder before re-use. Flush skin with planty of water for at least 15 minutes.

IF SWALLOWED: Drink milk, egg whites or getatin solution, or it these are not available, drink large amounts of water. Avoid alcohol. Call a physician immediately.

#### **ENVIRONMENTAL HAZARDS**

This product is toxic to fish. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

### DIRECTIONS FOR USE GENERAL CLASSIFICATION

It is a violation of Federal law to use this product in a manner inconsistent with its label. 63091215

**NET CONTENTS:** 

## **TOWER-CIDE**

### **ACTIVE INGREDIENTS:**


EPA REG. NO. 10088-40-EPA EST. NO. 10088-WI-1

## KEEP OUT OF REACH OF CHILDREN CAUTION

See side panel for additional precautionary statements.

Sold By:

# SPECIMEN LABEL



DESTICIOS IESTISTINO BASSI

EPA Rex No / 0088-90

This product is used to control algae, becteria and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algae growth, microbiological slime and other deposits.

An initial slug addition of 6.13 to 15.32 fluid ounces per 1000 gallons of water to provide a concentration of 48 to 120 parts per million based on the total weight of water in the system is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 1.53 to 15.32 fluid ounces per 1000 gallons of water (12 to 120 parts per million) should be employed every 2 to 5 days of as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

### STORAGE AND DISPOSAL

Do not contaminate water, food or feed by storage or disposal.

STORAGE: Store in a dry place no lower in temperature that 50°F, or higher than 120°F.

CONTAINER DISPOSAL: Triple rinse (or equivalent). Then offer for recycling or reconditioning or puncture and dispose of in a sanitary landfill, or inclneration, or, if allowed by state and local authorities, by burning. If burned, stay out of smoke.

PESTICIDE DISPOSAL: Wastes resulting from the use of this product may be disposed of on site or at an approved waste disposal facility.