



**AQUAPHASE**

**S-TEC-6**

Trademark  
CHLORINE COMPOSITION

**AQUAPHASE**

**FOR INDUSTRIAL USE ONLY  
STORE IN DRY AREA**

**LABORATORIES Inc.**

**ADRIAN, MICHIGAN 49221**

**ACCEPTED**

2/2/73

UNDER THE FEDERAL INSECTICIDE  
FUNGICIDE AND RODENTICIDE ACT  
FOR ECONOMIC POISON REGISTER-  
ED UNDER NO. 10336-3 SUBJECT

**ACTIVE INGREDIENT**

**SODIUM DICHLORO-S-TRIAZINETRIONE**

Percent  
by Weight:  
**100%**

**CONTENTS: NET WEIGHT \_\_\_\_\_ LB.**

**E.P.A. REG. NO. 10336-3**

**DANGER KEEP OUT OF REACH OF CHILDREN**

**CORROSIVE** May cause eye or skin damage. Do not get in eyes or on skin. Dust may be irritating if inhaled. Avoid breathing dust. Harmful if swallowed.

**"FIRST AID: External:** In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, get prompt medical attention."

**Internal:** If swallowed, feed bread soaked in milk. Follow with olive or cooking oil. Call a physician immediately."

**"STRONG OXIDIZING MATERIAL:** Contact with organic material may cause fire. Will burn with the evolution of toxic and irritating chlorine-containing gases. Avoid contact with organic material, moisture and heat. Store away from flammable material. Retie polyethylene liner when using this product."

**APPLICATIONS**

THIS PRODUCT IS INTENDED FOR USE IN CONTROLLING BACTERIA. FOR USE IN NORTHEAST UNITED STATES CLIMATES AS MICHIGAN, OHIO, INDIANA, AND ILLINOIS FOR CONTROLLING BACTERIAL GROWTH IN OPEN RECIRCULATING COOLING WATER SYSTEMS, OR ONCE THROUGH SYSTEMS.

**DIRECTIONS FOR USE:** ADD TO SUMP INITIALLY WHEN THE SYSTEM IS VISIBLY FOULED WITH SLIME OR EFFICIENCY IS IMPARED. 1/4 LB. PER 1000 GALLONS OF WATER CONTAINED IN THE SYSTEM. CHECK CHLORINE RESIDUAL WITH TEST KIT AND MAINTAIN 0.6 ppm FOR ABOUT 4 HOURS. IF SYSTEM IS BADLY FOULED WITH SLIME AND DEBRIS, CLEAN MANUALLY BEFORE USING THIS PRODUCT. REPEAT DOSAGE AS NEEDED TO MAINTAIN 0.6 ppm. KEEP pH OF WATER BETWEEN 7.2 - 7.5 WITH A KIT FOR pH CONTROL.

Do not reuse container. **DESTROY WHEN EMPTY.**  
Sold by **AQUAPHASE LABORATORIES, INC.,** Adrian, Michigan 49221



AQUAPHASE

S-TEC-6

Trade Name  
CHLORINE COMPOSITION

# AQUAPHASE

FOR INDUSTRIAL USE ONLY  
STORE IN DRY AREA

LABORATORIES Inc.

ADRIAN, MICHIGAN 49221

2/2/73  
10336-3

### ACTIVE INGREDIENT

SODIUM DICHORO-S TRIAZINETRIONE

Percent  
by Weight:  
100%

CONTENTS: NET WEIGHT \_\_\_\_\_ LB.

E.P.A. REG. NO. 10336-3

### DANGER KEEP OUT OF REACH OF CHILDREN

**CORROSIVE** May cause eye and skin damage. Do not get in eyes. Avoid contact with skin. Dust may be irritating if inhaled. Avoid breathing dust. Harmful to water.

**FIRST AID** External In case of contact, immediately flush eyes with plenty of water for at least 15 minutes. For eyes, get prompt medical attention.

Internal If swallowed, feed bread crackers to milk. Follow with olive or cooking oil. Call a physician immediately.

**STRONG OXIDIZING MATERIAL** Contact with organic material may cause fire. Will burn with the evolution of toxic and irritating chlorine containing gases. Avoid contact with organic material, moisture and heat. Store away from flammable materials. Retie polyethylene liner when using this product.

### APPLICATIONS

THIS PRODUCT IS INTENDED FOR USE IN CONTROLLING BACTERIA FOR USE IN NORTHEAST UNITED STATES CLIMATES AS MICHIGAN, OHIO, INDIANA AND ILLINOIS FOR CONTROLLING BACTERIAL GROWTH IN OPEN RECIRCULATING COOLING WATER SYSTEMS DRAINAGE THROUGH SYSTEM.

**DIRECTIONS FOR USE** ADD TO SYSTEM INITIALLY WHEN THE SYSTEM IS VISIBLY FOUL WITH SLIME OR EFFICIENCY IS IMPAIRED. 1.4 LB PER 1000 GALLONS OF WATER CONTAINED IN THE SYSTEM. CHECK CHLORINE RESIDUAL WITH TEST KIT AND MAINTAIN 0.6 ppm FOR ABOUT 4 HOURS IF SYSTEM IS BADLY FOULED WITH SLIME AND DEBRIS. CLEAN MANUALLY BEFORE USING THIS PRODUCT. REPEAT DOSAGE AS NEEDED TO MAINTAIN 0.6 ppm. KEEP pH OF WATER BETWEEN 7.2 - 7.5 WITH A KIT FOR pH CONTROL.

Do not reuse container. **DESTROY WHEN EMPTY**  
© 1973 AQUAPHASE LABORATORIES, INC. Adrian, Michigan 49221