



# AQUAPHASE S-TEC-6A

Sold By: <sup>Trademark</sup>  
CHLORINE COMPOSITION

# AQUAPHASE

FOR INDUSTRIAL USE ONLY  
STORE IN DRY AREA

LABORATORIES Inc.

ADRIAN, MICHIGAN 49221

## ACTIVE INGREDIENT

TRICHLORO-S-TRIAZINETRIONE  
(90% Available Chlorine)

Percent  
by Weight:  
100%

CONTENTS: NET WEIGHT \_\_\_\_\_ LB.

E.P.A. REG. NO. 10336-7

## DANGER KEEP OUT OF REACH OF CHILDREN

**CORROSIVE** May cause eye or skin damage, do not get in eyes or on skin or clothing. Dust may be irritating if inhaled. Avoid breathing dust. Harmful if swallowed.

**FIRST AID:** External: In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, get prompt medical attention."

Internal: If swallowed, feed bread soaked in milk. Follow with olive or cooking oil. Call a physician immediately."

**STRONG OXIDIZING MATERIAL:** Contact with organic material may cause fire. Will burn with the evolution of toxic and irritating chlorine-containing gases. Avoid contact with organic material, moisture and heat. Store away from flammable material. Retie polyethylene liner when using this product."

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Do not contaminate water by cleaning of equipment, or disposal of wastes. Apply this product only as specified on this label.

## APPLICATIONS

THIS PRODUCT IS INTENDED FOR USE IN CONTROLLING GROWTH OF BACTERIA. FOR USE IN NORTHEAST UNITED STATES CLIMATES AS MICHIGAN, OHIO, INDIANA, AND ILLINOIS, IN OPEN RECIRCULATING COOLING WATER SYSTEMS, OR ONCE THROUGH SYSTEMS.

**DIRECTIONS FOR USE:** ADD TO SUMP INITIALLY WHEN THE SYSTEM IS VISIBLY FOULED WITH SLIME OR EFFICIENCY IS IMPARED. 1/2 OZ. PER 1000 GALLONS OF WATER CONTAINED IN THE SYSTEM. CHECK CHLORINE RESIDUAL WITH TEST KIT AND MAINTAIN 0.6 ppm FOR ABOUT 4 HOURS. IF SYSTEM IS BADLY FOULED WITH SLIME AND DEBRIS, CLEAN MANUALLY BEFORE USING THIS PRODUCT. REPEAT DOSAGE AS NEEDED TO MAINTAIN 0.6 ppm. KEEP pH OF WATER BETWEEN 7.2 - 7.5 WITH A KIT FOR pH CONTROL. ONE TABLET WEIGHS 1/2 OZ. AND DISSOLVES IN 80-100 HOURS IN THE SUMP. 1/2 OZ. IN 5000 GALLONS OF WATER = 0.7 ppm AVAILABLE CHLORINE WHEN COMPLETELY DISSOLVED.

DISCARD WHEN EMPTY. Rinse thoroughly with water to clean before discarding.