



AQUAPHASE

S-TEC-11A

Sold By:

AQUAPHASE LABORATORIES

**FOR INDUSTRIAL USE ONLY
STORE IN DRY AREA**

ADRIAN, MICHIGAN 49221

ACCEPTED
MAR 6 1975
96
UNDER THE FEDERAL INSECTICIDE
FUNGICIDE AND RODENTICIDE ACT
FOR ECONOMIC POISON REGISTERED
UNDER NO. 10336-11

Active ingredients: 35 percent
Disodium cyanodithioimidocarbonate 14.7 percent
Potassium N-methyldithiocarbamate 20.3 percent
Inert ingredients 65 percent

Weight per gallon 10.0 lb.
Weight of active ingredients per gallon 3.5 lb.

CONTENTS: NET WEIGHT _____ LB.

E. P. A. REG. NO. 10336-11

E.P.A. ESTABLISHMENT NO. 10336-MI-1

DANGER KEEP OUT OF REACH OF CHILDREN

Causes eye damage and skin irritation. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

FIRST AID: In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes call a physician. Remove and wash contaminated clothing before reuse.

If swallowed, give patient doses of powdered charcoal immediately or all he can swallow of raw egg whites, milk, gruel, or flour and water. Then induce vomiting with salt, soap, or mustard in warm water. Call a physician immediately.

Do not reuse empty drum. Return to drum reconditioner or destroy by perforating or crushing and burying in a safe place.

This product is toxic to fish. Treated effluent should be discharged where it will drain to lakes, streams, ponds, or public water.

APPLICATIONS

S-TEC-11A IS USED TO INHIBIT THE GROWTH OF ALGAE, BACTERIA, AND FUNGI IN RECIRCULATING COMMERCIAL AND INDUSTRIAL COOLING WATER SYSTEMS. BEFORE TREATMENT WITH S-TEC-11A, SYSTEMS MUST BE CLEANED TO REMOVE ALGAE GROWTH, MICROBIOLOGICAL SLIME, AND OTHER DEPOSITS. THEN THE SYSTEM SHOULD BE TREATED WITH AN INITIAL SLUG ADDITION OF 1.5 TO 3.0 FLUID OUNCES OF S-TEC-11A PER 1000 GALLONS OF WATER IN THE SYSTEM. REPEAT THE INITIAL DOSAGE UNTIL CONTROL IS EVIDENT. SUBSEQUENT SLUG ADDITIONS OF 0.5 TO 3.0 FLUID OUNCES OF S-TEC-11A PER 1000 GALLONS OF WATER SHOULD BE MADE EVERY 1 TO 5 DAYS OR AS NEEDED. THE REQUIRED FREQUENCY OF TREATMENT DEPENDS ON THE RELATIVE AMOUNT OF BLEEDOFF AND THE SEVERITY OF THE MICROBIOLOGICAL PROBLEM. SLUG ADDITIONS OF S-TEC-11A SHOULD BE MADE TO THE SUMP OF WATER COOLING TOWERS.

Do not reuse container. **DESTROY WHEN EMPTY**
SOLD BY: AQUAPHASE LABORATORIES, INC., ADRIAN, MICHIGAN 49221