

BEST DOCUMENT AVAILABLE

PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTIONS: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

FIRST AID: If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or, if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Do not discharge into lakes, streams, ponds or public waters unless in accordance with an NPDES permit. For guidance, contact your regional office of the EPA.

STORAGE AND DISPOSAL: Keep container closed when not in use. Do not reuse empty container. Discard in trash receptacle. Do not contaminate water, food, or feed by storage or disposal.

CALGON

NO. 85 ALGAECIDE

For Controlling the Growth of Algae or Slime Bacteria in Cooling Towers of Evaporative Condenser Systems

ACTIVE INGREDIENT:

Poly [oxyethylene(dimethyliminio)ethylene-(dimethyliminio) ethylene dichloride] 30.0%
INERT INGREDIENT. 70.0%

This product contains 2.67 lb. of active ingredient per gallon and weighs 8.9 lb. per gallon.

KEEP OUT OF REACH OF CHILDREN.

CAUTION

See Additional Precautions and First Aid Procedures on Side Panel.

NOT FOR HOME USE.

ONLY FOR SALE TO, USE, AND STORAGE BY SERVICE PERSONS

E.P.A. Reg. No. 10445- —

EPA Est. No. 10445-MO-1

Net Contents: 1 U.S. Gal. 7 Fl. Oz.
(4 Liters)

CALGON CORPORATION
ST. LOUIS, MO 63166

DIRECT

GENERAL CLASSIFICATION:

It is a violation of Federal law to use this product in a manner inconsistent with its label.

NO. 85 Algaecide is used to control algae growth in recirculating commercial cooling towers. Prior to its use, an initial slug addition of 1 lb. Algaecide per 1,000 gallons of water, based on a system, is recommended. If the algae problem is evident.

Subsequent additions may be made. For drip feeding, use one gallon for each 1 gpm head. This Algaecide on a continuous basis of 0.47 to 4.75 ounces per 40 ppm should be employed. The frequency of addition of bleed-off and the severity of slug additions should be as recommended on the water towers.

AUG 6 1984

10445-84

BEST DOCUMENT AVAILABLE

CALGON

NO. 85 ALGAECIDE

For Controlling the Growth of Algae or Slime Bacteria
in Cooling Towers of Evaporative Condenser Systems

ACTIVE INGREDIENT:

Poly (oxyethylene(dimethyliminio)ethylene-
(dimethyliminio) ethylene dichloride) 30.0%
INERT INGREDIENT. 70.0%

This product contains 2.67 lb. of active ingredient per
gallon and weighs 8.9 lb. per gallon.

KEEP OUT OF REACH OF CHILDREN.

CAUTION

See Additional Precautions and First Aid Procedures on Side
Panel.

NOT FOR HOME USE.

ONLY FOR SALE TO, USE, AND STORAGE BY SERVICE PERSONS

F.P.A. Reg. No. 10445- _____

EPA Est. No. 10445-MO-1

Net Contents: 1 U.S. Gal. 7 Fl. Oz.
(4 Liters)

CALGON CORPORATION
ST. LOUIS, MO 63166

DIRECTIONS FOR USE

GENERAL CLASSIFICATION:

It is a violation of Federal law to use this product in a
manner inconsistent with its labeling.

NO. 85 Algaecide is used to control algae, bacteria, and fungi
in recirculating commercial and industrial water cooling
towers. Prior to its use, systems must be cleaned to remove
algae growth, microbiological slime, and other deposits. An
initial slug addition of 1.80 to 4.75 fluid ounces of NO. 85
Algaecide per 1,000 gallons of water to provide a concentration
of 16 to 40 ppm, based on the total weight of water in the
system, is recommended. Repeat initial dosage until control
is evident.

Subsequent additions may be continuously fed via Calgon's
Nos. 215 or 1075 Drip Feeders or it may be slug fed. When
drip feeding, use one gallon for six months (1/6 gal./mo.)
for each 1 gpm head. This will provide 4 to 5 ppm of No. 85
Algaecide on a continuous basis. If slug feeding, additions
of 0.47 to 4.75 ounces per 1,000 gallons of water (4 to
40 ppm) should be employed every 2-5 days, or as needed.
The frequency of addition depends upon the relative amount
of bleed-off and the severity of the microbiological problem.
Slug additions should be made into the sumps of cooling
water towers.

Product Made in U.S.A.

