JAN - 9 1997

Stanley C. Oslosky Calgon Corporation P.O. Box 1346 Pittsburg, PA 15230

SUBJECT: Cat-Floc T-2

EPA Registration No. 10445-122 Notification Per PR-Notice 95-2

Dear Mr. Oslosky:

This will acknowledge receipt of your notification, for an additional brand name (VeliGON T-2-M), submitted under the provisions of FIFRA section 3 (c) 9. Based on a review of the submitted material, the following comments apply.

The application is acceptable and the notification has been made a part of the records for this file.

Sincerely,

Wanda Y. Mitchell Notification Coordinator Antimicrobial Program Branch Registration Division (7505)

CONCURRENCES					
SYMBOL > 7505C					
SURNAME) WHONE!		· ·			
DATE 1-9-97					
EDA F 1999 14 (1999)	Th. 7 . 4 . 10 . 4 . 10	OFFICIAL FILE COPY			

Please read instructions on reverse before completing form	. Form Apr	proved. OMB No. 2070-0060. Approval expires 05-31-9				
United Sta		Registration OPP Identifier Number				
Environmental Prote	——————————————————————————————————————	Amendment 246269				
Washington, Di	NOTIFICATIO					
Application for Pesticide - Section I						
1. Company/Product Number 10445-122	2. EPA Product Me Johnson					
4. Company/Product (Name) Cat-Floc T-2	PM# 31	None Restricted				
5. Name and Address of Applicant (Include ZIP Code)		6. Expedited Review. In accordance with FIFRA Section 3(c)(3)				
Calgon Corporation P.O. Box 1346	(b)(i), my produc	(b)(i), my product is similar or identical in composition and labeling				
Pittsburgh, PA 15230	j	1.0.				
	LIA (log. No.	EPA Reg. No.				
Check if this is a new address		Product Name				
	Section - II					
Amendment - Explain below.		ted labels in response to				
Resubmission in response to Agency letter dated		etter dated " Application.				
Notification - Explain below.	Other - E	Other - Explain below.				
Explanation: Use additional page(s) if necessary. (For s	section I and Section II)					
Add the word "plant" after "sewage		ronmental Hazards.				
nad the note plane ditter bounge						
	Section - III					
Material This Product Will Be Packaged In:						
Child-Resistant Packaging Unit Packaging	Water Soluble Packaging	2. Type of Container				
Yes Yes	Yes	Metal Plastic				
No No	No No	Glass Paper				
Jertification must Unit Packaging wgt. Conta						
	(a) Patail Containes	5. Location of Label Directions				
	(s) Retail Container	On Label				
Label Container	Listaneant D Orl	On Labeling accompanying product				
6, Manner in Which Label is Affixed to Product Lithograph Other Other Stenciled						
	Section - IV					
1. Contact Point (Complete items directly below for identi	fication of individual to be contacte	d, if necessary, to process this application.)				
Name	Title	Telephone No(Include Area Code)				
Stanley C. Oslosky	Mgr., Product Regu	ulations 412-494-8802				
Certification 6. Data Application						
I certify that the statements I have made on this form and all attachments thereto are true, accurate and complete. I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law.						
2. Signature	3. Title					
Stanley C. Osloby	Mgr., Product Regu	lations				
4. Typod Name	5. Date	· · · · · · · · · · · · · · · · · · ·				
Stanley C. Oslosky	12/9/96	:::: 61/4/Q				

LABEL

Cat-Floc® T-2

Water Treatment For the Control of Molluscs in Water Supplies

Active Ingredients:

poly (dimethyl diallyl ammonium chloride)	-	 33%
Inert ingredients		 67%

CAUTION

KEEP OUT OF REACH OF CHILDREN

See Side Panel for Additional Precautionary Statements

EPA Registration No. 10445-122 EPA Establishment No. 10445-PA-1

Precautionary Statements

HAZARD TO HUMANS AND DOMESTIC ANIMALS
KEEP OUT OF REACH OF CHILDREN
CAUTION: AVOID CONTACT WITH SKIN EYES OR CLOTHING. In case of contact
immediately flush eyes or skin with plenty of water. Get medical attention if irritation
persists.

Statement of Practical Treatment

If Swallowed: Do not induce vomiting. Drink large quantities of water. Never give anything by mouth to an unconscious or convulsing person.

If In Eyes: Flood eyes with water for at least 15 minutes.

If On Skin: Wash thoroughly with soap and water.

Environmental Hazards

This pesticide is toxic to fish and aquatic invertebrates. Do not use in facilities discharging directly or indirectly to estuarine or marine environments. Do not discharge into lakes, streams, ponds or public waters unless in accordance with the requirements of a National Pollution Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

1/4

Storage and Disposal

Prohibitions - Do not contaminate water, food, or feed by storage or disposal. Keep container closed when not in use.

Pesticide Disposal - Pesticide wastes are toxic. Improper disposal of excess pesticide, spray mixture, or rinsate is a violation of Federal Law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste Representative at the nearest EPA regional office for guidance.

Container Disposal - Plastic Containers—Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or by incineration, or, if allowed by state and local authorities, by burning. If burned, stay out of smoke.

Directions for Use

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

Cat-Floc® T-2 should be added to the system at a rate of 0.36 fluid ounces to 3.6 fluid ounces of Cat-Floc® T-2 per 1000 gallons of intake water. Additions should occur at a point sufficiently inside the intake pipe to prevent any release of Cat-Floc® T-2 into the intake source (5 to 10 feet for normal flow operations). Addition should be made through a supply line placed inside the intake pipe or in some locations as to ensure that no contamination of public water occurs in the event of a break. Feed exits must be equipped with a pressure check valve at the feed line exit to seal the feed line when intake flow stops. Feed pumps must be designed to shut down when intake pumps stop. Planned shut downs shall require feed pumps to be stopped 1/2 hour prior to shut down.

Limit residues of Poly (N,N-dimethyl diallyl ammonium chloride) in the finished potable water to no more than 50 ppm.

pDADMAC CERTIFIED TO ANSI/NSF 60

POTABLE WATER MAXIMUM NSF CERTIFIED DOSAGE - 23.8 MG/L PLANT NO. USA

