IN THE EVENT OF AN EMERGENCY INVOLVING CHLORINE, CALL 800-424-9300 FOR ADVICE AND ASSISTANCE, 24 HOUR SERVICE.

CHEMICAL TRANSPORTATION EMERGENCY CENTER, WASHINGTON, D. C.

# BONDICIDE NO. 2-2321

FOR SLIME, ALGAE AND FUNGUS CONTROL IN COOLING TOWERS

#### **COMPOSITION**

**Active Ingredient** 

PERCENT BY WEIGHT

10.0 percent

Poly[oxyethylene(dimethyliminio)ethylene(dimethyliminio)ethylene dichloride] 10.0 percent

Inert Ingredient

90.0 percent

Weight per gallon
Weight of active ingredient per gallon

8.49 pounds 0.85 pound

### CAUTION

## Keep Out of the Reach of Children

Harmful if swallowed. Avoid contact with skin and eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists, get medical attention. Avoid contamination of food.

ACCEPTED

8--7-72.

UNDER THE FEDERAL INSECTICIDE FUNGICIDE AND RUD. NTW. OC. ACT FOR ECONOMIC POLIUN RUB STEELED LINDER NO. 10477-9

This product is toxic to fish. Do not add treated effluent to lakes, streams, or ponds. Do not contaminate water by cleaning of equipment or disposal of waste. Use only as directed on label. Do not reuse container. Destroy when empty.

U.S. Gallons

### **APPLICATION**

EPA Reg No. 10477-9

BONDICIDE NO. 2-2321 is used to control algae, bacteria and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 5.7 to 14.25 fluid ounces of BONDICIDE NO. 2-2321 per 1000 gallons of water to provide a concentration of 48 to 120 parts per million of BONDICIDE NO. 2-2321 based on the total weight of water in the system is recommended. Repeat until control is achieved. Subsequent slug additions of 1.43 to 14.25 fluid ounces of BONDICIDE NO. 2-2321 per 1000 gallons of water (12 to 120 parts per million of BONDICIDE 2-2321) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

MANUFACTURED

BOND CHEMICALS, INC.

1500 BROOKPARK ROAD • CLEVELAND, OHIO 44109