

## PRECAUTIONARY STATEMENTS

Hazardous to Humans and Domestic Animals

### CAUTION

Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

### FIRST AID

If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution or if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

### ENVIRONMENTAL HAZARDS

This pesticide is toxic to fish. Keep out of lakes, streams, or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds, or public water. For guidance, contact the regional office of the Environmental Protection Agency.

## STORAGE AND DISPOSAL

### 1 PROHIBITIONS

Do not contaminate water, food, or feed by storage or disposal. Open dumping is prohibited.

### 2 STORAGE

Do not store more than 30 containers of this product. Damaged containers should be repaired or replaced. Drums for disposal. Spills should be absorbed or flushed to sand and disposed of in accordance with local regulations. Keep container closed when not in use.

### 3 PESTICIDE DISPOSAL

Wastes resulting from the use of this product should be disposed of on site or at an approved waste disposal facility.

### 4 CONTAINER DISPOSAL

Triple rinse (or equivalent). Then offer for recycling or reuse, if available, or for disposal. Do not reuse for food, feed, or other uses. Do not reuse for agricultural purposes. Do not reuse for other uses.

### 5 GENERAL

Consult label for complete instructions. For more information, contact the manufacturer.

# EX-A(1)

Active Ingredient: 1,2-Dichloro-4,4'-oxybis(2-chlorobenzene)  
Trade Name: EX-A(1)

### PERCENTAGE

90.0

This product contains 0.42 lb of active ingredient per gallon and weighs 8.39 lb per gallon.

## KEEP OUT OF REACH OF CHILDREN

## CAUTION

### STATEMENT OF PRACTICAL TREATMENT

If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution or if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

See Side Panel For Additional Precautionary Statements



Manufactured by  
**SUHM LABORATORIES, INC.**

1111 Industrial Blvd., Green Bay, Wisconsin  
54303-1111, U.S.A.

## DIRECTIONS FOR USE

### GENERAL CLASSIFICATION

This product is classified as a Restricted Use Pesticide. It is to be used only by or under the direct supervision of a person certified with this labeling.

EX-A(1) is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algae growth, microbiological slime, and other deposits. An initial slug addition of 13.6 to 36.3 fluid ounces of EX-A(1) per 1000 gallons of water to provide a concentration of 96 to 240 parts per million of EX-A(1) based on the total weight of water in the system is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 3.6 to 36.3 fluid ounces of EX-A(1) per 1000 gallons of water (24 to 240 parts per million of EX-A(1)) should be employed every 2 to 5 days if needed. The frequency of addition depends upon the relative amount of biofouling and the severity of the problem. Slug additions should be made in the sump of water cooling towers.

EX-A(1) is used to control algae, bacteria, and fungi in industrial air washing systems. The system should be cleaned to remove algae, bacteria, and other deposits. An initial slug addition of 20 to 200 fluid ounces of EX-A(1) per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 3.6 to 36.3 fluid ounces of EX-A(1) per 1000 gallons of water should be employed every 2 to 5 days if needed. The frequency of addition depends upon the relative amount of biofouling and the severity of the problem. Slug additions should be made in the sump of the water washing system.

EX-A(1) is used to control algae, bacteria, and fungi in industrial air washing systems. The system should be cleaned to remove algae, bacteria, and other deposits. An initial slug addition of 20 to 200 fluid ounces of EX-A(1) per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 3.6 to 36.3 fluid ounces of EX-A(1) per 1000 gallons of water should be employed every 2 to 5 days if needed. The frequency of addition depends upon the relative amount of biofouling and the severity of the problem. Slug additions should be made in the sump of the water washing system.