

Chemquest 201

NOT REFINISHED
In Accordance with EPA Notice 82-2,
Based on the date of the label dated

ACTIVE INGREDIENT

Polychlorophenylene glycol, 2,4,6-trichlorophenyl ether
sulfonate, 2,4,6-trichlorophenyl ether

Net Content

1.0 gallon (128 fluid ounces) (3.785 liters) (3.785 L)

KEEP OUT OF REACH OF CHILDREN

CAUTION

PRECAUTIONARY STATEMENTS

HAZARDOUS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin and eyes.

FIRST AID: If swallowed, induce vomiting. If in eyes, flush with water. Avoid contact with skin and eyes.

ENVIRONMENTAL HAZARDS: To prevent contamination, keep out of rivers, streams, ponds, etc. Precautions may be required for fish ponds, ornamental ponds, dent, lakes, streams, ponds, and other water. For guidelines contact the regional office of the Environmental Protection Agency.

DIRECTIONS FOR USE

It is a violation of Federal law to use this product in a manner inconsistent with the labeling.

Chemquest 201 is used to control algae, bacteria, and fungus in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algae, microbial slime, and other deposits. An initial dosage of 6.13 to 15.32 fluid ounces of Chemquest 201 per 100 gallons of water to provide a concentration of 48 to 120 parts per million of Chemquest 201 based on the total weight of water in the system is recommended. Repeat initial dosage until control is evident.

Subsequent dosages of 1.53 to 15.32 fluid ounces of Chemquest 201 per 100 gallons of water (12 to 120 parts per million of Chemquest 201) should be applied every 2 to 5 days, or as needed. The frequency of application depends upon the relative amount of build-off and the severity of the microbial problem. Subsequent dosages should be made in the top of water cooling towers.

Chemquest 201 is used to control bacteria in industrial air washing systems that maintain high humidity in heating components. Prior to its use, systems should be cleaned to remove bacteria, slime, and other deposits. An initial dosage of 24.7 to 41.2 fluid ounces of Chemquest 201 per 100 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent dosages of 16.3 to 41.2 fluid ounces of Chemquest 201 per 100 gallons of water should be applied every 1 to 5 days, or as needed.

The frequency of application depends upon the relative amount of build-off and severity of the microbial problem. Subsequent dosages should be made to the supply of the water in the air washing system.

STORAGE AND DISPOSAL

Store in a cool, dry place. Protect from freezing and discoloration.

DO NOT REUSE: Containers more than 4 quarts in size leaking or damaged drums should be placed in overbank or other suitable disposal site. Do not reuse containers for food or a secondary use. Keep out of reach of children.

DO NOT REUSE DISPOSAL: Wastes may be recycled or disposed of in accordance with applicable local, state, and federal regulations.

CONTAINER DISPOSAL

Empty containers may be recycled. Refill containers are recommended for reuse. Do not reuse containers for food or a secondary use. Do not reuse containers for food or a secondary use. Do not reuse containers for food or a secondary use.

For more information, contact the manufacturer or distributor.

Manufactured by
FMC Corporation

14625 Sycamore Road
Carmichael, CA 95621

1993-20

EPA EST. NO.

1993-20