


EMERGENCY TELEPHONE NUMBERS
CHEMTREC: 800-424-9300
CANUTEC: 613-996-6666
Customer Care 800-872-1916

BAKER HUGHES
Baker Petrolite
 Baker Petrolite Corp
 12645 W. Airport Blvd.
 Sugar Land, TX 77478 U.S.A.

10707-38

10-02-2000

ACCEPTED
 OCT 0 2 2000
 Under the Federal Insecticide, Fungicide, and Rodenticide Act as amended, for the pesticide, registered under EPA Reg. No. 10707-38



PRECAUTIONARY STATEMENTS
 HAZARDS TO HUMANS AND DOMESTIC ANIMALS
DANGER

CORROSIVE. CAUSES EYE DAMAGE AND SKIN BURNS. MAY CAUSE ALLERGIC SKIN REACTION. HARMFUL IF INHALED. HARMFUL IF SWALLOWED. DO NOT GET IN EYES, ON SKIN OR ON CLOTHING. MIXERS, LOADERS AND OTHERS EXPOSED TO THIS PRODUCT MUST WEAR LONG-SLEEVED SHIRTS AND LONG PANTS; CHEMICAL RESISTANT GLOVES SUCH AS NITRILE OR BUTYL RUBBER; SHOES PLUS SOCKS; GOGGLES AND FACE SHIELD; AND CHEMICAL RESISTANT APRON. DISCARD CLOTHING OR OTHER ABSORBENT MATERIALS THAT HAVE BEEN SOILED OR HEAVILY CONTAMINATED WITH THIS PRODUCT'S CONCENTRATE. DO NOT REUSE THEM. FOLLOW MANUFACTURER'S INSTRUCTIONS FOR CLEANING/MAINTAINING PPE. IF NO SUCH INSTRUCTIONS FOR REMOVABLES EXISTS, USE DETERGENT AND HOT WATER. KEEP AND WASH PPE SEPARATE FROM OTHER LAUNDRY. USERS SHOULD WASH HANDS BEFORE EATING, DRINKING, CREAMING GUM, USING TOBACCO OR USING THE TOILET. USERS SHOULD REMOVE CLOTHING IMMEDIATELY IF PESTICIDE GETS INSIDE. THEN WASH THOROUGHLY AND PUT ON CLEAN CLOTHING. USERS SHOULD REMOVE PPE IMMEDIATELY AFTER HANDLING THIS PRODUCT, AS SOON AS POSSIBLE. WASH THOROUGHLY. THIS PRODUCT MAY CAUSE SKIN SENSITIZATION REACTIONS IN SOME PEOPLE.

ENVIRONMENTAL HAZARDS

THIS CHEMICAL IS TOXIC TO TERRESTRIAL AND AQUATIC PLANTS, FISH AND AQUATIC INVERTEBRATES. DO NOT DISCHARGE EFFLUENT CONTAINING THIS PRODUCT INTO LAKES, STREAMS, PONDS, ESTUARIES, OCEANS OR OTHER WATERS UNLESS IN ACCORDANCE WITH THE REQUIREMENTS OF NATIONAL POLLUTION DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT AND THE PERMITTING AUTHORITY HAS BEEN NOTIFIED IN WRITING PRIOR TO DISCHARGE. DO NOT DISCHARGE EFFLUENT CONTAINING THIS PRODUCT TO SEWER SYSTEMS WITHOUT PREVIOUSLY NOTIFYING THE LOCAL SEWAGE TREATMENT PLANT AUTHORITY. FOR GUIDANCE, CONTACT YOUR STATE WATER BOARD OR REGIONAL OFFICE OF THE EPA. DO NOT CONTAMINATE WATER BY CLEANING OF EQUIPMENT OR DISPOSAL OF WASTE. APPLY THIS PESTICIDE ONLY AS SPECIFIED ON THIS LABEL.

STORAGE AND DISPOSAL

PROHIBITIONS: THIS PRODUCT IS CORROSIVE TO MILD STEEL. DO NOT STORE OR TRANSPORT IN UNLINED METAL CONTAINERS. DO NOT CONTAMINATE FOOD OR FEED BY STORAGE, DISPOSAL OR CLEANING OF EQUIPMENT.
PESTICIDE DISPOSAL: PESTICIDE WASTES ARE ACUTELY HAZARDOUS. IMPROPER DISPOSAL OF EXCESS PESTICIDE OR RINSEATE IS A VIOLATION OF FEDERAL LAW. IF THESE WASTES CANNOT BE DISPOSED OF BY USE ACCORDING TO LABEL INSTRUCTIONS, CONTACT YOUR STATE PESTICIDE OR ENVIRONMENTAL CONTROL AGENCY OR THE HAZARDOUS WASTE REPRESENTATIVE AT THE NEAREST EPA REGIONAL OFFICE FOR GUIDANCE.
CONTAINER DISPOSAL: TRIPLE RINSE (OR EQUIVALENT). THEN OFFER FOR RECYCLING OR RECONDITIONING, OR PUNCTURE AND DISPOSE OF IN A SANITARY LANDFILL OR BY INCINERATION, OR, IF ALLOWED BY STATE AND LOCAL AUTHORITIES, BY BURNING. IF BURNED, STAY OUT OF SMOKE.
GENERAL: CONSULT FEDERAL, STATE OR LOCAL DISPOSAL AUTHORITIES FOR APPROVED ALTERNATIVE PROCEDURES.

Read Product Material Safety Data Sheet prior to use. **PRODUCT WARRANTY, DISCLAIMER AND LIMITATION OF LIABILITY ARE FOUND THEREIN.** Use of Product signifies agreement with these provisions.

BPC 68915

CONTROLS BACTERIA, FUNGI AND ALGAE IN INDUSTRIAL RECIRCULATING WATER COOLING TOWERS: CONTROLS BACTERIA AND FUNGI IN METAL WORKING FLUIDS CONTAINING WATER; CONTROLS SLIME-FORMING BACTERIA AND SULFATE-REDUCING BACTERIA IN OIL FIELD WATERS; CONTROLS BACTERIA AND FUNGAL SLIME IN PAPER MILLS; CONTROLS BACTERIA, FUNGI AND ALGAE IN INDUSTRIAL AIR-WASHER SYSTEMS; AND CONTROLS BACTERIA AND FUNGI IN ULTRA FILTRATION UNITS AND NON-MEDICAL/NON-POTABLE REVERSE OSMOSIS SYSTEMS.

ACTIVE INGREDIENTS:

- S-Chloro-2-methyl-4-isothiazolin-3-one..... 1.11%
- 2-Hexyl-4-isothiazolin-3-one..... 0.39%
- INERT INGREDIENTS:**..... 98.50%
- TOTAL:**..... 100.00%

KEEP OUT OF REACH OF CHILDREN
DANGER

SEE SIDE PANELS FOR ADDITIONAL PRECAUTIONARY STATEMENTS

STATEMENT OF PRACTICAL TREATMENT

IF SWALLOWED: DO NOT INDUCE VOMITING. DRINK PROMPTLY A LARGE QUANTITY OF EGGS WHITES, GELATIN SOLUTION, OR IF THESE ARE NOT AVAILABLE, DRINK LARGE QUANTITIES OF WATER. AVOID ALCOHOL. CALL A PHYSICIAN IMMEDIATELY. NEVER GIVE ANYTHING BY MOUTH TO AN UNCONSCIOUS PERSON.
 IF ON SKIN: WASH THOROUGHLY WITH SOAP AND WATER. REMOVE AND WASH CONTAMINATED CLOTHING BEFORE REUSE.
 IF IN EYES: FLUSH WITH PLENTY OF WATER FOR AT LEAST 15 MINUTES. CALL A PHYSICIAN.
 IF INHALED: REMOVE IMMEDIATELY TO FRESH AIR. IF NOT BREATHING, APPLY ARTIFICIAL RESPIRATION. IF BREATHING IS DIFFICULT, GIVE OXYGEN. CALL A PHYSICIAN.
NOTE TO PHYSICIAN: PROBABLE MUCOSAL DAMAGE MAY CONTRAINDICATE THE USE OF GASTRIC LAVAGE.

EPA REG. NO. 10 97-38
 EPA EST. NO. 10 97-38-007
 EPA EST. NO. 10 97-CA-012
 EPA EST. NO. 13797-0K-002
 EPA EST. NO. 107-PA-001
NET WEIGHT: 30 GALLONS/240 LBS.; 55 GALLONS/460 LBS.

Lea la hoja de datos de seguridad de materiales del producto antes de usarlo. LA GARANTIA DEL PRODUCTO, EL DESCARGO Y LA LIMITACION DE RESPONSABILIDAD SE ENCUENTRAN EN DICHS DOCUMENTOS. El uso del producto significa acuerdo con estas disposiciones.

DIRECTIONS FOR USE

IT IS A VIOLATION OF FEDERAL LAW TO USE THIS PRODUCT IN A MANNER INCONSISTENT WITH ITS LABELING.
 DO NOT APPLY THIS PRODUCT IN A MANNER THAT WILL CONTACT WORKERS OR OTHER PERSONS.

INDUSTRIAL RECIRCULATING WATER COOLING TOWERS

FOR THE CONTROL OF BACTERIA, ALGAE AND FUNGI, ADD BPC 68915 TO THE TOWER BASIN, DISTRIBUTION BOX OR SOME OTHER POINT TO INSURE UNIFORM MIXING.
INITIAL DOSE: WHEN THE SYSTEM IS NOTICEABLY SOILED, APPLY 1.26 TO 7.46 POUNDS (0.57 TO 3.36 FLUID OUNCES) OF BPC 68915 PER 1,000 GALLONS OF WATER IN THE SYSTEM. REPEAT UNTIL CONTROL IS ACHIEVED.
SUBSEQUENT DOSE: WHEN MICROBIAL CONTROL IS EVIDENT, ADD 0.3 TO 1.86 POUNDS (0.11 TO 0.67 FLUID OUNCES) OF BPC 68915 PER 1,000 GALLONS OF WATER IN THE SYSTEM WEEKLY OR AS NEEDED TO MAINTAIN CONTROL. BAILY FOULING SYSTEMS MUST BE CLEANED BEFORE TREATMENT IS BEGUN.

METAL WORKING FLUIDS CONTAINING WATER

TREATMENT:
 BPC 68915 IS RECOMMENDED FOR THE CONTROL OF BACTERIA AND FUNGI IN SOLUBLE AND EMULSIFIABLE TYPE AQUEOUS METALWORKING FLUIDS SUCH AS EMULSIFIED PETROLEUM OILS AND FORMULATIONS CONTAINING AN ANIONIC PATTY ACID SULFONATED RED OIL OR NONPHTHALENE SULFONATE. THESE FLUIDS ARE USUALLY PREPARED BY DILUTING THE PRODUCT CONCENTRATES 1:40 TO 1:60 WITH WATER.
FOR THE MAINTENANCE OF A NONFOULED SYSTEM, USE BPC 68915 AT 32 FLUID OUNCES PER 1,000 GALLONS OF EMULSION (2 POUNDS EVERY 4 WEEKS OR 32 TO 134 FLUID OUNCES PER 1,000 GALLONS OF WATER). USE AN INITIAL DOSE OF 10 TO 12 PPM. FOR A NOTICEABLY SOILED SYSTEM, USE AN INITIAL DOSE OF 64 TO 134 FLUID OUNCES PER 1,000 GALLONS OF EMULSION (4 TO 10 POUNDS) TO BE FOLLOWED BY SUBSEQUENT MAINTENANCE DOSAGES DEPENDING UPON THE TREATMENT INTERVAL NOTED ABOVE. A HIGHER DOSAGE RANGE AND/OR INCREASED FREQUENCY OF TREATMENT MAY BE REQUIRED DEPENDING UPON RATE OF DILUTION OF THE PRESERVATIVE WITH MAKEUP FLUID, THE NATURE AND SEVERITY OF CONTAMINATION, LEVEL OF CONTROL REQUIRED, FILTRATION EFFECTIVENESS, SYSTEM DESIGN, ETC.
 THE PRESERVATIVE SHOULD BE DISPENSED INTO THE USE DILUTION OF THE METALWORKING FLUID USING A METERING PUMP.

OIL FIELD INJECTION WATERS

FOR THE CONTROL OF SLIME-FORMING BACTERIA AND SULFATE-REDUCING BACTERIA IN OIL FIELD WATERS, CONCENTRATE WITH 67 TO 332 PPM BPC 68915 DEPENDING ON THE SEVERITY OF CONTAMINATION.
INITIAL DOSE: ADD 166 TO 332 PPM BPC 68915 (6.9 TO 13.9 GALLONS OR 58.0 TO 116.8 POUNDS BPC 68915 PER 1,000 BARRELS OF WATER) AT A POINT IN THE SYSTEM WHERE IT WILL BE UNIFORMLY MIXED. REPEAT TREATMENT AFTER THREE DAYS OR AS NEEDED UNTIL CONTROL IS ACHIEVED.
SUBSEQUENT DOSE: ADD 67 TO 166 PPM BPC 68915 (2.8 TO 6.9 GALLONS OR 23.5 TO 58.0 POUNDS BPC 68915 PER 1,000 BARRELS OF WATER) EVERY SEVEN DAYS OR AS NEEDED TO MAINTAIN CONTROL.

PAPER MILLS

TREATMENT: BPC 68915 IS RECOMMENDED FOR THE CONTROL OF BACTERIAL AND FUNGAL SLIME IN THE PRODUCTION OF PAPER.

POINT OF ADDITION: BPC 68915 SHOULD BE ADDED TO A POINT IN THE SYSTEM TO INSURE UNIFORM MIXING SUCH AS THE BEATER, HYDROPLUMPER OR PAM OR BROKE STORAGE PUMPS.

DOSEAGE: APPLY 0.44 TO 1.5 POUNDS (7 TO 23 FLUID OUNCES) OF BPC 68915 PER 10M (DRY BASIS) OF PULP OR PAPER PRODUCED AS A SLUG DOSE. IF NEEDED, REPEAT DAILY. BAILY FOULED SYSTEMS SHOULD BE CLEANED BEFORE INITIAL TREATMENT.

AIR-WASHER SYSTEMS

ADD TO THE AIR WASHER SUMP OR CHILL WATER SUMP TO INSURE UNIFORM MIXING. 35 TO 883 PPM BPC 68915 (0.3 TO 7.46 POUNDS OR 4.5 TO 113 FLUID OUNCES) OF BPC 68915 PER 1,000 GALLONS OF WATER IN THE SYSTEM) DEPENDING UPON SEVERITY OF CONTAMINATION TO CONTROL BACTERIA, FUNGI AND ALGAE WHICH CAUSE FOULING IN INDUSTRIAL AIR WASHER SYSTEMS.

INTERMITTENT OR SLUG METHOD

INITIAL DOSE: WHEN THE SYSTEM IS NOTICEABLY SOILED, APPLY 148 TO 883 PPM BPC 68915 (1.26 TO 7.46 POUNDS OR 19 TO 113 FLUID OUNCES) OF BPC 68915 PER 1,000 GALLONS OF WATER IN THE SYSTEM). REPEAT UNTIL CONTROL IS ACHIEVED.

SUBSEQUENT DOSE: WHEN MICROBIAL CONTROL IS EVIDENT, ADD 35 TO 219 PPM BPC 68915 (0.3 TO 1.86 POUNDS OR 4.5 TO 28 FLUID OUNCES) OF BPC 68915 PER 1,000 GALLONS OF WATER) WEEKLY OR AS NEEDED TO MAINTAIN CONTROL.

CONTINUOUS FEED METHOD

INITIAL DOSE: WHEN THE SYSTEM IS JUST NOTICEABLY SOILED, APPLY 148 TO 883 PPM BPC 68915 (1.26 TO 7.46 POUNDS OR 19 TO 113 FLUID OUNCES) OF BPC 68915 PER 1,000 GALLONS OF WATER IN THE SYSTEM).
SUBSEQUENT DOSE: MAINTAIN THIS TREATMENT LEVEL BY ADDING A CONTINUOUS FEED OF 35 TO 219 PPM (0.3 TO 1.86 POUNDS OR 4.5 TO 28 FLUID OUNCES) OF BPC 68915 PER 1,000 GALLONS OF MAKEUP WATER).

BAILY FOULED SYSTEMS MUST BE CLEANED BEFORE INITIAL TREATMENT.

NOTE: FOR USE ONLY IN INDUSTRIAL AIR-WASHING SYSTEMS THAT MAINTAIN EFFECTIVE MIST ELIMINATING COMPONENTS.

ULTRA FILTRATION UNITS AND NON-MEDICAL/NON-POTABLE REVERSE OSMOSIS SYSTEMS

BPC 68915 IS RECOMMENDED FOR THE CONTROL OF BACTERIA AND FUNGI IN ULTRA FILTRATION UNITS AND NON-MEDICAL/NON-POTABLE REVERSE OSMOSIS SYSTEMS. USE OF BPC 68915 IN POTABLE WATER OR DIALYSIS IS PROHIBITED.
 ADD 19 TO 333 PPM OF BPC 68915 (0.15 TO 5 PPM ACTIVE INGREDIENTS) INTO INDUSTRIAL ULTRA FILTRATION OR REVERSE OSMOSIS SYSTEMS BY EITHER CONTINUOUS FEED OR PERIODIC INJECTION. COMPATIBILITY OF BPC 68915 WITH REVERSE OSMOSIS MEMBRANES SHOULD BE CONFIRMED WITH MEMBRANE MANUFACTURERS.

FOR THE CONTROL OF BACTERIA AND FUNGI IN CARBON BEDS, ADD 18 TO 333 PPM BPC 68915 (0.15 TO 5 PPM ACTIVE INGREDIENT) BY EITHER CONTINUOUS OR BATCH FEED.

FOR PERIODIC MEMBRANE CLEANING, ADD 6.4 TO 1.0 POUND OF BPC 68915 TO EVERY 128 GALLONS OF CLEANING SOLUTION (6 TO 15 PPM ACTIVE INGREDIENT). BAILY FOULED SYSTEMS SHOULD BE CLEANED BEFORE TREATMENT IS BEGUN.

Corrosive Liquid, Toxic N.O.S.
 (contains 5 - Chloro - 2 - methyl - 4 - isothiazolin - 3 - one), 8,
 (6-1); UN 2922. II