COMPOSITION

DW 5 1972 10778—1

FOR THE AND REPORTS OF A OTHER Percent by weight
TO ATTORISE STREETS OF STREETS

TO ATTORISE ST

APPLICATION

Vaporene W is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 3.96 to 9.81 fluid ounces of Vaporene W per 1000 gallons of water, to provide a concentration of 32 to 80 parts per million of Vaporene W based on the total weight of water in the system is recommended. Subsequent slug additions of 0.98 to 9.81 fluid ounces of Vaporene W per 1000 gallons of water (8 to 80 parts per million of Vaporene W) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

CAUTION

KEEP OUT OF THE REACH OF CHILDREN

Harmful if swallowed. Avoid contact with skin and eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists get medical attention. Avoid contamination of food.

This product is toxic to fish. Do not add treated effluent to lakes, streams or ponds. Do not contaminate water by cleaning of equipment or disposal of waste. Use only as directed on label. Do not reuse container. Destroy when empty.

MANUFACTURED BY

METROPOLITAN REFINING CO., INC.

The Foremost Producers of Water Treatments Industrial Chemicals

50-23 — 23rd STREET

LONG ISLAND CITY, NEW YORK 11101

EPA REG. No. 10778-1