

ACCEPTED
 9-11-97
 Under the Federal Insecticide, Fungicide, and
 Rodenticide Act as amended, for the
 pesticide, registered under
 EPA Reg No 10807-189



MISTY

W-15-16

ACTIVE INGREDIENTS:
 Poly(oxyethylene)(dimethylamino)ethylene-
 (dimethylamino)ethylene dichloride 15.0%
 INERT INGREDIENTS: 85.0%
 TOTAL: 100.0%

KEEP OUT OF REACH OF CHILDREN.
CAUTION:
 See back panel for additional precautionary statements.

NET CONTENTS 1 QUART (0.95 LITERS)

W-15-16

DIRECTIONS FOR USE: It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

W-15-16 is used to control the growth of algae in swimming pools, exterior spas, whirlpools, hot tubs, decorative fountains, and ponds that do not contain fish. For maximum effectiveness pools, spas, whirlpools, hot tubs, decorative fountains, and ponds containing heavy growth of algae should be cleaner prior to using W-15-16.

For pools having just visible algae growth add an initial dose of 50 to 77 fluid ounces of W-15-16 per 10,000 gallons of water and remove settled algae debris by cleaning. For treatment of a freshly cleaned and filled pool add initially 27 to 50 fluid ounces of W-15-16 per 10,000 gallons of water. Subsequent additions of 9 to 18 fluid ounces of W-15-16 per 10,000 gallons of water should be made every 5 to 7 days after initial treatment for maintenance.

Spas, whirlpools, hot tubs, decorative fountains, and ponds having just visible algae growth require an initial dose of 5 to 8 fluid ounces of W-15-16 per 1000 gallons of water. For treatment of a freshly cleaned spa, whirlpool, hot tub, decorative fountain, or pond, add initially 3 to 5 fluid ounces of W-15-16 per 1000 gallons of water. Subsequent additions of 1 to 2 fluid ounces of W-15-16 should be made every 5 to 7 days after initial treatment for maintenance.

W-15-16 will prevent growth of most algae during the off-season winter months when pools are not in use. For pools which have been properly treated during the swimming season and are free of visible algae, add 27 to 43 fluid ounces of algaeicide per 10,000 gallons of water. If at the end of the swimming season pools have some visible algae growth, add 50 to 77 fluid ounces per 10,000 gallons. It is necessary that a uniform distribution of algaeicide throughout the water and the pool be made for maximum effectiveness. If pool is not covered, it may be necessary to repeat the treatment one or more times during the season.

W-15-16 is compatible with those chemicals normally used to treat pools and spas and is effective at both acid and alkaline pH. W-15-16 can be used in pools and spas treated with chlorine chemicals and may reduce the amount of those chemicals normally required. However, do not mix W-15-16 with concentrated dry or liquid chlorine products.

W-15-16 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 4.0 to 10.0 fluid ounces of W-15-16 per 1000 gallons of water to provide a concentration of 32 to 80 parts per million of W-15-16 based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 1.0 to 10.0 fluid ounces of W-15-16 per 1000 gallons of water (8 to 80 parts per million of W-15-16) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

W-15-16 is used to control bacteria in industrial air-washing systems that maintain effective mist elimination components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 14.8 to 24.7 fluid ounces of W-15-16 per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 10.1 to 24.7 fluid ounces of W-15-16 per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Slug additions may be made to the sump or to the water collection trays or the airwash system.

PRECAUTIONARY STATEMENTS: HAZARDS TO HUMANS AND DOMESTIC ANIMALS:

CAUTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

STATEMENT OF PRACTICAL TREATMENT: IF SWALLOWED: Drink promptly a large quantity of milk, egg whites, gelatin solution, or if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish and aquatic organisms. Do not contaminate water by the cleaning of equipment or disposal of wastes. Keep out of lakes, streams, or ponds. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance, contact your State Water Board or Regional Office of the EPA.

STORAGE & DISPOSAL: Do not contaminate water, food, or feed by storage or disposal. **STORAGE:** Keep container closed when not in use. Leaking or damaged containers should be placed in a plastic bag and discarded in trash. Mop up spills with clear water. All pesticides should be kept out of reach of children and stored away from food. **DISPOSAL:** Do not reuse empty container. Wrap container and place in trash.

EPA REG. NO. 10807-189 EPA EST. NO. 10807-GA-1
 HMRATING: Health-1, Flammability-1, Reactivity-1, Personal Protection-B.

MADE IN THE USA BY:
AMREP, INC.
 990 Industrial Park Drive
 Marietta, GA 30062

PM 32
 10807-189
 9/11/97
 Page 1 of 1