

Algae-Trol 108

For Controlling Algae, Bacteria And Fungi In Recirculating Commercial And Industrial Cooling Water Towers And Air Washing Systems.

ACTIVE INGREDIENT:

Polyoxyethylene (dimethyliminio) ethylene-
(dimethyliminio) ethylene dichloride 15.0%

INERT INGREDIENT 85.0%

This product contains 1.29 lb. of active ingredient per gallon and weighs 8.58 lb. per gallon.

**KEEP OUT OF REACH OF CHILDREN
CAUTION**

PRECAUTIONARY STATEMENTS

HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

FIRST AID: If swallowed, drink promptly a large quantity of milk, egg whites or a fat solution, or if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Keep out of lakes, streams, ponds, or public water. For guidance, contact the regional office of the Environmental Protection Agency.

10827-69
JUN 15 1981
Under the Federal Insecticide,
Fungicide, and Rodenticide Act,
as amended, for the pesticide
registered under
EPA Reg. No.

DIRECTIONS FOR USE

GENERAL CLASSIFICATION:

This product is used to control algae, bacteria and fungi in recirculating commercial air water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, micro slime and other deposits. An initial slug addition of 4 to 10 fluid ounces of this product per 1000 gallons of water to provide a concentration of 32 to 80 parts per million of this algacide to the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 1 to 10 fluid ounces of this product per 1000 gallons of water (parts per million) of this product should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbial problem. Slug additions should be made in the sump of water cooling towers.

This product is used to control bacteria in industrial air washing systems that maintain and eliminate components. Prior to its use, systems should be cleaned to remove bacteria and other deposits. An initial slug dose of 14.8 to 24.7 fluid ounces of this product per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 10.1 to 24.7 fluid ounces of this product per 1000 gallons of water should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Slug additions may be made to the sump or to the water trays of the airwash system.

STORAGE & DISPOSAL: Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal or cleaning of equipment. Rinsate that cannot be used or reprocessed should be disposed of in an approved manner for pesticides or buried in a safe place away from water. Open dumping is prohibited.

- METAL CONTAINERS: Triple rinse and offer for recycling, reconditioning, or disposal in an approved landfill or bury in a safe place.
- PLASTIC CONTAINERS: Do not use empty container. Triple rinse and incinerate or dispose in an approved landfill or bury in a safe place.

EPA REG. NO. 10827-69

EPA EST. NO. 10827-70

NET CONTENTS

GALS.



INDUSTRIAL SOLVENTS

DIVISION OF CHEMICAL SPECIALTIES, INC. • SAN MARCO, TEXAS



10827-69
JUN 15 1981

Under the Federal Insecticide, Fungicide, and Rodenticide Act as amended, for the pesticide registered under EPA Reg. No.

DIRECTIONS FOR USE

GENERAL CLASSIFICATION:

This product is used to control algae, bacteria and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 4 to 10 fluid ounces of this product per 1000 gallons of water to provide a concentration of 32 to 80 parts per million of this algicide, based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 1 to 10 fluid ounces of this product per 1000 gallons of water (8 to 80 parts per million) of this product should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

This product is used to control bacteria in industrial air washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 14.8 to 24.7 fluid ounces of this product per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 10.1 to 24.7 fluid ounces of this product per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Slug additions may be made to the sump or to the water collection trays of the airwash system.

STORAGE & DISPOSAL: Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal or cleaning of equipment. Rinsate that cannot be used or reprocessed should be disposed of in a landfill approved for pesticides or buried in a safe place away from water supplies. Open dumping is prohibited.

- | | |
|--|--|
| <input type="checkbox"/> METAL CONTAINERS Triple rinse and offer for recycling, reconditioning, or disposal in an approved landfill or bury in a safe place. | <input type="checkbox"/> PLASTIC CONTAINERS Do not reuse empty container. Triple rinse and incinerate or dispose of in an approved landfill or bury in safe place. |
|--|--|

EPA REG NO. 10827-69

EPA EST. NO. 10827-TX-1

NET CONTENTS

GALS.

AL SOLVENTS

ALTIAS, INC. • SAN MARCOS, TEXAS

