

Under the Federal Insecticide, Fungicide, and Rodenticide fict, as amended, for the pesticide

### aquaserv engineers, inc.

2431 EAST 56th STREET, LOS ANGELES, CALIFORNIA 90058 • TEL. 582-8246

EPA EST. NO. 10932-CA-1 EPA REG. NO. 10932-10

# PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS

**DANGER:** Highly corrosive. Causes skin and eye damage. May be fatal if swallowed. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Irritating to nose and throat. Avoid breathing dust. Remove and wash contaminated clothing before reuse.

**ENVIRONMENTAL HAZARDS:** This product is toxic to fish. Do not discharge into lakes, streams, ponds, or public waters.

#### 'HYSICAL AND CHEMICAL HAZARDS

TRONG OXIDIZING AGENT: Strong oxidizing agent. Mix only with water. Use clean, dry utensils. Do not add this product to any dispensing device containing remnants of any other product. Such use may cause a violent reaction leading to fire or explosion. Contamination with moisture, organic matter, or other chemicals may start a chemical reaction, with generation of heat, liberation of hazardous gases, and possible generation of fire and explosion. In case of contamination or decomposition, do not reseal container. If possible, isolate container in open air or well-ventilated area. Flood with large volumes of water, if necessary.

## 7410

#### **MICROBIOCIDE**

FOR THE CONTROL OF ALGAE, BACTERIA, FUNGI, AND SLIMES IN INDUSTRIAL RECIRCULATING WATER COOLING TOWERS.

### DANGER

#### PRACTICAL TREATMENT (FIRST AID):

If swallowed: Feed bread soaked in milk, followed by olive oil or cooking oil. Call a physician immediately.

If on skin: Brush off excess chemical and flush with cold water for at least 15 minutes. If irritation persists, get medical attention.

If in eyes: Flush with cold water for at least 15 minutes, Get medical attention.

#### **DIRECTIONS FOR USE**

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

Clean badly fouled recirculating cooling tower systems before starting treatment. When algae, fungi, or slime is first noted, add 2 to 4 ounces of 7410 per 1000 gallons of water in the system. Test for free chlorine by use of chlorine tester; dosage should be 10 to 20 ppm free chlorine for 5 to 10 minutes. Repeat dosage daily until control is evident. When control is evident, add 1 to 2 ounces of 7410 per 1000 gallons of water in system to provide 5 to 10 ppm free chlorine by test, each 7 days to maintain control. Feed required dosage of 7410 to system where the product will be uniformly mixed, e.g., circulating pump suction area.

STORAGE AND DISPOSAL: Keep product dry in tightly closed container when not in use. Store in a cool, dry, well-ventilated area away from heat or open flame. In case of decomposition isolate container, if possible, and flood with large amounts of water to dissolve all material before discarding. Place in trash collection or dispose of in approved landfill area, or bury in a safe place.

**NET WEIGHT: 20 POUNDS**