

APPLICATION

SLIMETROL is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algae growth, microbiological slime and other deposits. An initial slug addition of 15.20 to 38.0 fluid ounces of SLIMETROL per 1000 gallons of water, to provide a concentration of 120 to 300 parts per million of SLIMETROL based on the total weight of water in the system is recommended. Repeat if necessary until control is evident. Subsequent slug additions of 3.80 to 38.0 fluid ounces of SLIMETROL per 1000 gallons of water (30 to 300 parts per million of SLIMETROL) should be employed every 2 to 5 days or as needed. The frequency of addition depends on the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

EPA EST. 11497-TX-1

SLIMETROL

COMPLETE MICROBIOLOGICAL CONTROL
ACTIVE INGREDIENTS:

Poly (oxyethylene (dimethyliminio) ethylene dichloride)

INERT:

Jan 16, 1975 114


Wt./gal.....

Wt. of Active ingredient/gal..

CAUTION! KEEP OUT OF REACH OF CHILDREN

See Side Panel for additional cautions

EPA REG. NO. 11497-2



ENVIRO CHEM CORPORATION

P. O. BOX 29113 DALLAS TEXAS

SLIMETROL

COMPLETE MICROBIOLOGICAL CONTROL
ACTIVE INGREDIENTS:

Poly (oxyethylene (2-methyliminio) ethylene
(dimethyliminio) ethylene dichloride) 4%

WATER:96%


Jan 16, 1975 11497-2

gal.....8.39 Lbs.
of Active ingredient/gal.....0.34 Lbs.

CAUTION! KEEP OUT OF REACH OF CHILDREN
See Side Panel for additional cautions.

EPA REG. NO. 11497-2

ENVIRONMENTAL CHEM CORPORATION



P. O. BOX 29113 DALLAS TEXAS 75229

WARNING: Harmful if swallowed. Avoid contact with skin and eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists get medical attention. Avoid contamination of food.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Do not contaminate water by cleaning of equipment, or disposal of wastes. Apply this product only as specified on this label.

BEGIN treatment when the system is in jeopardy of becoming affected or after cleaning systems whose efficiency is already impaired. Badly fouled systems must be cleaned before treatment is begun.

NET CONTENTS: GALS.