BAF-N-30

[illegible]

APPLICATIONS

BAF-N-30 is used to inhibit the growth of algae, bacteria, and fungi in recirculating [illegible] and industrial cooling [illegible] systems. Before treatment with BAF-N-30, system [illegible] should be cleaned to remove algae, [illegible] biological slime, and other deposits. Then the system should be [illegible] with an initial slug [illegible] of 6.9 to 13.5 fluid ounces of BAF-N-30 per 1,000 [illegible] of water in the system. Repeat the initial dosage until control is evident. Subsequent slug additions of 2.3 to [illegible] fluid ounces of BAF-N-30 per 1,000 gallons of water should be made every 4 to 5 days [illegible] The required frequency of treatment depends on the relative amount of [illegible] and the [illegible] microbiological problem. Slug additions of BAF-N-30 should be made to the sump of water cooling towers.

WARNING!

[illegible]

Do not [illegible] on skin, or on clothing [illegible]

[illegible]