

ALGACIDE-L

WARNING-KEEP OUT REACH OF CHILDREN

HARMFUL OR FATAL IF SWALLOWED OR ABSORBED THROUGH SKIN. INJURIOUS TO EYES. CAUSES SKIN IRRITATION. RAPIDLY ABSORBED THROUGH SKIN.

DO NOT GET INTO EYES, ON SKIN OR CLOTHING. WASH THOROUGHLY AFTER HANDLING. WASH CLOTHES BEFORE REUSE. KEEP PACKAGE TIGHTLY CLOSED WHEN NOT IN USE. USE WITH ADEQUATE VENTILATION.

FIRST AID

IN CASE OF CONTACT FLUSH EYES IMMEDIATELY WITH PLENTY OF WATER FOR AT LEAST 15 MINUTES AND GET MEDICAL ATTENTION. FOR SKIN WASH WITH SOAP AND PLENTY OF WATER.

NOTE TO PHYSICIAN

THIS PRODUCT IS A METABOLIC STIMULANT. CAUSES HYPERTHERMIA. TREAT SYMPTOMATICALLY.

FISH AND WILDLIFE PRECAUTIONS

THIS PRODUCT IS TOXIC TO FISH AND WILDLIFE. TREATED EFFLUENT SHOULD NOT BE DISCHARGED WHERE IT WILL DRAIN INTO LAKES, STREAMS, PONDS, OR PUBLIC WATER. USE ONLY AS DIRECTED.

DIRECTIONS FOR USE

ALGACIDE-L IS USED TO CONTROL ALGAE, BACTERIA, AND FUNGI IN RECIRCULATING COMMERCIAL AND INDUSTRIAL WATER COOLING TOWERS.

INITIAL DOSE: WHEN THE SYSTEM IS FOULED, APPLY A DOSE OF 53.7 TO 107.4 FLUID OUNCES PER 1,000 GALLONS OF WATER IN THE SYSTEM. REPEAT UNTIL CONTROL IS ACHIEVED.

SUBSEQUENT DOSE: WHEN MICROBIAL CONTROL IS EVIDENT, ADD 26.9 TO 53.7 FLUID OUNCES PER 1,000 GALLONS OF WATER IN THE SYSTEM EVERY 2-5 DAYS OR AS NEEDED TO MAINTAIN CONTROL. BADLY FOULED SYSTEMS MUST BE MANUALLY OR CHEMICALLY CLEANED BEFORE TREATMENT IS BEGUN. ALGACIDE-L MAY BE ADDED DIRECTLY TO THE SUMP OF WATER COOLING TOWERS.

E.P.A. REG. NO. 11576-2

... FOR CHEMICAL CONTROL OF
ALGAE AND SLIME IN WATER COOLING
TOWERS



314 Spears Ave. Phone 267-6781

ACTIVE INGREDIENTS

SODIUM PENTACHLOROPHEN-
ATE-----7.9%

SODIUM SALT OF OTHER
CHLOROPHENOLS-----1.1%

TOTAL-----9.0%

INERT INGREDIENTS---91.0%

WEIGHT ONE GALLON-9.221lb

DO NOT REUSE EMPTY DRUM.
RETURN TO RECONDITIONER
OR DESTROY BY PERFORATING
OR CRUSHING AND BURYING
IN A SAFE PLACE.

DATE

GROSS

TARE

NET

CUSTOMER

NUMBER

ACCEPTED

8-2-72

UNDER THE FEDERAL INSECTICIDE
FUNGICIDE AND RODENTICIDE ACT
FOR ECONOMIC PEACE
ED UNDER NO. 11576-2