

ALGAECIDE - 66

ACTIVE INGREDIENTS.....10.32%
n-alkyl(60%C₁₄, 30%C₁₆, 5%C₁₈, 5%C₁₂)dimethyl
benzyl ammonium chlorides..... 8.32%
bis(tributyltin)oxide..... 1.67%
trisodium n-hydroxyethyl ethylenediamine
triacetate..... 0.33%
INERT INGREDIENTS.....89.68%

DANGER-KEEP OUT OF REACH OF CHILDREN --SEE PRECAUTIONS BELOW

CORROSIVE. CAUSES EYE DAMAGE AND SKIN IRRITATION. DO NOT GET INTO EYES, ON SKIN OR CLOTHING. WEAR GOGGLES OR FACE SHIELD AND RUBBER GLOVES WHEN HANDLING. HARMFUL OR FATAL IF SWALLOWED. AVOID CONTAMINATION OF FOOD.

FIRST AID: IN CASE OF CONTACT, IMMEDIATELY FLUSH EYES OR SKIN WITH PLENTY OF WATER FOR AT LEAST 15 MINUTES. FOR EYES, CALL A PHYSICIAN. REMOVE AND WASH CONTAMINATED CLOTHING BEFORE REUSE.

IF SWALLOWED, DRINK PROMPTLY A LARGE QUANTITY OF MILK, EGG WHITES, GELATIN SOLUTION OR IF THESE ARE NOT AVAILABLE, DRINK LARGE QUANTITIES OF WATER. AVOID ALCOHOL. CALL A PHYSICIAN IMMEDIATELY.

NOTE TO PHYSICIAN: PROBABLE MUCOSAL DAMAGE MAY CONTRAINDICATE THE USE OF GASTRIC LAVAGE. MEASURES AGAINST CIRCULATORY SHOCK; RESPIRATORY DEPRESSION AND CONVULSION MAY BE NEEDED.

COOLING TOWER ALGAECIDE
KEEPS TOWER WATER CLEAN AND FREE
OF GROWING ALGAE--CONTROLS ALGAE SLIME

DIRECTIONS FOR USE

ALGAECIDE-66 IS USED TO CONTROL ALGAE, BACTERIA AND FUNGI IN RECIRCULATING COMMERCIAL AND INDUSTRIAL WATER COOLING TOWERS. PRIOR TO ITS USE, SYSTEMS MUST BE CLEANED TO REMOVE ALGAE GROWTH, MICROBIOLOGICAL SLIME AND OTHER DEPOSITS. ALGAECIDE-66 SHOULD BE ADDED TO THE SUMP OF WATER COOLING TOWERS.

INITIAL DOSE: APPLY 2 GALLONS OF THIS PRODUCT PER 5,000 GALLONS OF WATER IN THE SYSTEM. REPEAT UNTIL CONTROL IS ACHIEVED.

SUBSEQUENT DOSE: WHEN MICROBIAL CONTROL IS EVIDENT ADD 1/2 GALLONS OF THE PRODUCT PER 5,000 GALLONS OF WATER IN THE SYSTEM EVERY 7 DAYS OR AS NEEDED TO MAINTAIN CONTROL.

DO NOT REUSE EMPTY DRUM. RETURN TO DRUM RECONDITIONER OR DESTROY BY PERFORATING OR CRUSHING AND BURYING IN A SAFE PLACE.

E.P.A. REG. NO. 11576-7

WEIGHT ONE GALLON--8.7 LBS.

THIS PRODUCT IS TOXIC TO FISH. DO NOT DISCHARGE TREATED EFFLUENT INTO LAKES, STREAMS, PONDS, OR PUBLIC WATER.

... FOR CHEMICAL CONTROL OF
ALGAE AND SLIME IN WATER COOLING
TOWERS



314 Spears Ave. Phone 267-6781

DATE
GROSS
TARE
NET
CUSTOMER
NUMBER

