

1 oz. = 2 Tablespoons

UNDER THE FEDERAL INSECTICIDE
FUNGICIDE AND RODENTICIDE ACT
FOR ECONOMIC POISON REGISTER
ED UNDER NO. 2010-1

DIRECTIONS FOR USE

INITIAL DOSE: When system is noticeably fouled add 1-2 gallons WT 2000 S to each 5000 gallons of water contained in the system. Repeat as needed until control is evident.

PERIODIC DOSE: Once microbial control is evident, or where the system is under control, add 1-3 quarts WT 2000 S to each 5000 gallons of water contained in the system every 7 days or sooner should visible growth appear.

For best results, clean heavily contaminated systems before treatment with this product. If soap or anionic detergent is used, rinse thoroughly before charging with WT 2000 S. Introduce WT 2000 S into the system on the downward side of the pump following the boiler.

Do not be alarmed with the sudden appearance of organic debris in the system during the first week of operation. This is normal and is a good indication that WT 2000 S has effectively penetrated and dislodged dead organic matter which tenaciously adheres to metal and wooden surfaces. This debris should be removed from the system to avoid clogging of screens and pipes.

When WT 2000 S is used as directed, it will aid in controlling and/or preventing the development of unsanitary slime conditions which are unsightly, produce foul odors and which are often the cause of equipment breakdown.

WT 2000 S is compatible with virtually all corrosion inhibition additives, but should not be used in the presence of soap or other anionic detergents. WT 2000 S at use dilution is non-corrosive to inanimate surfaces.

DANGER

Keep Out of Reach of Children. Causes severe eye and skin damage. Do not get in eyes, on skin or on clothing. Wear goggles or face shield, and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

FIRST AID

In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash all contaminated clothing before reuse. If swallowed, drink milk, egg whites, gelatin solution, or if these are not available, drink large quantities of water. Call a physician.

Rinse empty container thoroughly with water and discard.

CORROSIVE

Note to Physician: Probable mucosal damage may contraindicate the use of gastric lavage. Measures against circulatory shock, respiratory depression, and convulsions may be needed.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water.