Sol-Vet 421 X

A BACTERIOSTAT AND ALGAECIDE FOR THE CONTROL OF BACTERIAL SLIMES AND ALGAE IN OPEN RECIRCULATING COOLING SYSTEMS

ACTIVE INGREDIENT:	15% by weight
POLY [OXYETHYLENE (DIMETHYLIMINIO) ETHYLENE	
(DIMETHYLIMINIO) ETHYLENEDICHLORIDE]	15% by weight
INERT INGREDIENT: 85	5.0% by weight
Weight per gallon	8.58 pounds
Weight of active ingredient per gallon	1.29 pounds

CAUTION: KEEP OUT OF REACH OF CHILDREN.

Harmful if swallowed. Avoid contact with skin and eyes. In case of eye contact, flush with plenty of water for at least 15 minutes.

If eye irritation persists get medical attention.

Avoid contamination of food.

This product is toxic to fish. Do not add treated effluent to lakes, streams or ponds.

Do not contaminate water by cleaning of equipment or disposal of waste.

Use only as directed on label.





ANDERSO CORPÜR 1733 WALNU KANSAS CITY,

INDUSTRIAL WATE

DIRECTIONS FOR USE: Sol-Vet 421X is used to control algae lating commercial and industrial water cooling towers. Prior to it to remove algal growth, microbiological slime and other depodes 3.9 to 9.75 fluid ounces of Sol-Vet 421X per 1000 gallons of tion of 32 to 80 parts per million of Sol-Vet 421X based on the system is recommended. Repeat if necessary until control is evice of 1.0 to 9.75 fluid ounces of Sol-Vet 421X per 1000 gallon million of Sol-Vet 421X) should be employed every two to five day of addition depends upon the relative amount of bleedoff and problem. Slug additions should be made in the sump of cooling

EPA Registrd

21 X

D ALGAECIDE OF BACTERIAL E IN OPEN ING SYSTEMS

ETHYLENE	. 15%	% by	weight
E]	. 15%	6 by	weight
	85.0%	6 by	weight
• • • • • • • • • • • • • • • • • • • •		8.58	pounds
• • • • • • • • • • • •		1.29	pounds

I OF CHILDREN.

and eyes. In case of eye contact, utes.

treated effluent to lakes, streams

uipment or disposal of waste.

12016-2 With Comments



ANDERSON-STOLZ CORPORATION

1733 WALNUT STREET KANSAS CITY, MO. 64108

INDUSTRIAL WATER TREATMENTS

DIRECTIONS FOR USE: Sol-Vet 421X is used to control algae, bacteria and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 3.9 to 9.75 fluid ounces of Sol-Vet 421X per 1000 gallons of water, to provide a concentration of 32 to 80 parts per million of Sol-Vet 421X based on the total weight of water in the system is recommended. Repeat if necessary until control is evident. Subsequent slug additions of 1.0 to 9.75 fluid ounces of Sol-Vet 421X per 1000 gallons of water (8 to 80 parts per million of Sol-Vet 421X) should be employed every two to five days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the microbiological problem. Slug additions should be made in the sump of cooling towers.

EPA Registration No. 12016-2

ACCEPTED WITH COMMENTS