# Sol-Vet 423

### COOLING TOWER ALGAECIDE-SLIMICIDE

ACTIVE INGREDIENT	
n-Alkyl (50% C <sub>14</sub> , 40% C <sub>12</sub> , 10% C <sub>16</sub> )	
dimethyl benzyl ammonium chloride	. 10%
INERT INGREDIENTS	90%
Weight @ gal	23 lb.
Weight of active ingredient @ gal	

## DANGER: KEEP OUT OF REACH OF CHILDREN

Corrosive. Causes severe eye and skin damage. Do not get in eyes, on skin or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

This product is toxic to fish. Do not discharge treated effluent from cooling towers where it will drain into lakes, ponds, or streams.

#### FIRST AID:

In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash contaminated clothing before reuse. If swallowed, drink **promptly** a large quantity of milk, egg whites, gelatin solution or if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately. Do not reuse container. After use, wash thoroughly and discard in safe place.

#### NOTE TO PHYSICIAN:

Probably mucosal damage may contraindicate the use of gastric lavage. Measures against circulatory shock as well as oxygen and measures to support breathing manually or mechanically may be needed. If persistent, convulsions may be controlled by the cautious intravenous injection of a short-acting barbiturate drug.



# ANDERSON-STOLZ CORPORATION

1733 WALNUT STREET KANSAS CITY, MO. '64108

INDUSTRIAL WATER TREATMENTS

12016-4

DIRECTIONS FOR USE: Sol-Vet 423 Cooling Tower Algaecide-Slimicide controls olgal, and bacterial slime in industrial recirculating water cooling towers. The growth of algae and slime-producing microorganisms can seriously reduce the efficiency of the entire cooling system.

Initial Dose: In a clean system, with no algae or microbial slime growth visible, add three gallons of Sol-Vet 423 Algaecide-Slimicide per 10,000 gallons of cooling water. If algae and microbial slime growth are visible, add six gallons of Sol-Vet 423 Algaecide-Slimicide per 10,000 gallons of cooling water. Repeat until control is achieved. Badly fouled systems must be cleaned before treatment is added. Apply at a point in the system where this product will be uniformly mixed.

**Subsequent Treatment:** After the initial dose, add one to three gallons of Sol-Vet 423 Algaecide-Slimicide per 10,000 gallons of cooling water once per week or more often if needed, to prevent algae or microbial slime growth.

Net weight

EPA Registration No. 12016-4