

WATER TOWER TREATMENT

DIRECTIONS FOR USE

Apply MISCO Water Tower Treatment when the system is in jeopardy of becoming affected, or after cleaning system whose efficiency is already impaired.

Initial Dose: This should not be done until system has been cleaned with MISCO Chemical Cleaner or otherwise cleaned and prepared NOT using soap or other anionic detergents. 1-2 gallons Water Tower Treatment to each 5,000 gallons of water contained in the system (20-40 ppm active quaternaries). Repeat until control is evident.

Periodic Dose: When system is in control, add 1-3 quarts Water Tower Treatment to each 5,000 gallons of water contained in the system every 7 days or sooner should visible growth appear. (5-15 ppm active quaternaries).

IMPORTANT: Periodic dose amounts may be weekly or as needed. Algae potential and amount of sunshine compensation for natural water evaporation and bleed off should be considered in an efficient preventative program for your particular system.

For best results; clean heavily contaminated systems before treatment with this product. If soap or anionic detergent is used, rinse thoroughly before charging with Water Tower Treatment. Apply Water Tower



misco
INTERNATIONAL
CHEMICALS, INC.

ACCEPTED

UNDER THE FEDERAL INSECTICIDE
FUNGICIDE AND RODENTICIDE ACT
FOR ECONOMIC POISON REGISTRATION
ED UNDER NO. 12310-2

WATER TOWER TREATMENT

WATER TOWER TREATMENT

When MISCO Water Tower Treatment is used as directed, it will aid in controlling and/or preventing the development of unsanitary algae slime conditions which are unsightly, produce foul odors and which are often the cause of equipment breakdown.

Water Tower Treatment is compatible with virtually all corrosion inhibition additives, but should not be used in the presence of soap or other anionic detergents. Water Tower Treatment at use dilution is non-corrosive to inanimate hard surfaces.

DANGER: Keep Out of Reach of Children. Corrosive. Causes severe eye and skin damage. Do not get in eyes, on skin or on clothing. Wear water goggles or face shield, and rubber gloves

- Concentrated Algacide and Slimecide for Industrial recirculating water cooling towers.
- Helps keep water cooling tower systems clean and free of visible algae slimes

Nonflammable and nonvolatile

ACTIVE INGREDIENTS

n-Alkyl (60% C₁₄, 30% C₁₆, 5% C₁₂, 5% C₁₈)

dimethyl benzyl ammonium chlorides

n-Alkyl (68% C₁₂, 32% C₁₄) dimethyl ethylbenzyl ammonium chlorides

INERT INGREDIENTS

5%

5%

90%

100%

DANGER Keep Out of Reach of Children. See Other Precautionary Statements on Right Side Panel

Rinse empty container thoroughly with water and discard.

NOTE TO PHYSICIAN: Probable mucous membrane irritation may contraindicate the use of gastric lavage. Measures against circulatory, respiratory depression and convulsion may be needed.

NET CONTENTS

GALS EPA Reg. No. 12310-2

 **INTERNATIONAL
CHEMICALS, INC.**