

AETNA

CHEMICAL CORPORATION

ACTANA ALGECIDE

COOLING TOWER ALGECIDE

ACTANA ALGECIDE is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers.

Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 10.1 to 25.25 fluid ounces of ACTANA ALGECIDE per 1,000 gallons of water, to provide a concentration of 80 to 200 parts per million of ACTANA ALGECIDE based on the total weight of water in the system is recommended. Subsequent slug additions of 2.52 to 25.25 fluid ounces of ACTANA ALGECIDE per 1,000 gallons of water (20 to 200 parts per million of ACTANA ALGECIDE) should be employed every 2 to 5 days as needed. Repeat until control is achieved. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

CAUTION: KEEP OUT OF REACH OF CHILDREN. Harmful if swallowed. Avoid contact with skin and eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists get medical attention. Avoid contamination of food.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds or public water. Do not contaminate water by cleaning of equipment or disposal of waste. Use only as directed on label. Do not re-use container. Destroy when empty.

Active Ingredients	Percent by Weight
Poly [oxyethylene (dimethyliminio) ethylene (dimethyliminio-ethylene dichloride)]	6.0%
Inert Ingredient	94.0%
Weight per gallon	8.43 pounds
Weight of Active Ingredient per gallon	.51 pound

EPA Reg. No. 12463-1



CHEMICAL CORPORATION

EAST PATERSON, NEW JERSEY 07407 / (201) 796-0230

ACCEPTED WITH COMMENTS

ACCEPTED