



AQUATHERM, INC.

INDUSTRIAL WATER CONTROL

2233 W. 2nd STREET • SANTA ANA, CALIF.

MICROBIOCIDES 210

EPA Reg. No. 12468-R

Active Ingredient	20.0%
Poly[oxyethylene(dimethyliminio)ethylene(dimethyliminio)ethylene dichloride].	
Inert Ingredient	80.0%

Microbiocide 210 is used to control algae, bacteria and fungi in recirculating water cooling towers. Prior to its use, systems should be cleaned to remove algal growth, slime and other deposits. An initial slug addition of 2.9 to 7.3 fluid ounces of Microbiocide 210 per 1000 gallons of water to provide a concentration of 24 to 60 parts per million of Microbiocide 210 based on the total weight of water in the system is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 0.73 to 7.3 fluid ounces of Microbiocide 210 per 1000 gallons of water (6 to 60 parts per million of Microbiocide 210) should be employed every 2 to 5 days or as needed. Frequency of addition depends upon the amount of bleedoff and the severity of the microbiological problem. Slug additions should be made to the cooling tower sump.

CAUTION KEEP OUT OF REACH OF CHILDREN

Harmful if swallowed - Avoid contact with skin & eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists get medical attention. Avoid contamination of food.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds or public water. Do not contaminate water by cleaning of equipment or disposal of waste. Use only as directed. Do not reuse container. Destroy when empty.

ACCEPTED
12468-1

ACCEPTED WITH COMMENTS