

QUALITY WATER TREATMENTS SINCE 1917

ACCEPTED
October 4, 1972
UNDER THE FEDERAL INSECTICIDE
FUNGICIDE AND RODENTICIDE ACT
FOR ECONOMIC POISON REGISTERED
UNDER NO. *12475-1*

DIXIE COMPOUND WORKS

MANUFACTURERS AND DISTRIBUTORS

INDUSTRIAL CHEMICALS, SUPPLIES AND EQUIPMENT

P.O. BOX 41, PHONE 293-2081, DAYTON, OHIO 45419

DIXICIDE

ALGAE - SLIME CONTROLLER

EPA REG. NO. 12475-1

Composition

Active -	
Poly(oxyethylene(dimethyliminio)ethylene(dimethyliminio)ethylene dichloride)	15.0%
Inert -	
.....	85.0%
Weight per gallon	8.58 lbs.
Weight of active ingredient per gallon	1.29 lbs.

CAUTION: KEEP OUT OF REACH OF CHILDREN

Harmful if swallowed. Avoid contact with skin and eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists, get medical attention. Avoid contamination of food.

This product is toxic to fish: Do not add treated effluent to lakes, streams, ponds, or public water systems. Use only as directed on label. Destroy empty container. Do not contaminate water by cleaning of equipment or disposal of waste.

Applications

DIXICIDE is used to control algae, bacteria, and fungi in recirculating commercial and industrial water-cooling towers. Prior to its use, systems must be cleaned to remove algae growth, microbiological slime, and other deposits. An initial slug addition of 4.0 to 9.80 fluid ounces of DIXICIDE per 1000 gallons of water, to provide a concentration of 32 to 80 parts per million of DIXICIDE based on the total weight of water in the system. Repeat until control is achieved. Subsequent slug additions of 1.0 to 9.80 fluid ounces of DIXICIDE per 1000 gallons of water (8 to 80 parts per million of DIXICIDE) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water-cooling towers.

DISTRIBUTED BY:

NET CONTENTS _____ GALLONS