## HEISLER GREEN CHEMICAL CO.

111.5 WEST 47TH PLACE

CHICAGO, ILLINOIS

PHONE YArds 7-1218

ACCEPTED

FOR ECONOMIC POLEN, J. STER-ED UNDER NO. 24 P. L. STERECT

FEB 2 6 1973
A 2 4 - 4 Algae Treatment

TO ATTACHED COMMENTS. EPA REG. NO. 12480-1

12480 -1

NET CONTENTS \_\_\_\_ GAL.

## **Application**

A24-4 Algae Treatment is used to control algae, bacteria and fungi in industrial recirculating water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 10.10 to 25.25 fluid ounces of A24-4 per 1000 gallons of water, to provide a concentration of 80 to 200 parts per million of A24-4 based on the total weight of water in the system is recommended. Repeat until control is achieved. Subsequent slug additions of 2.52 to 25.25 fluid ounces of A24-4 Algae Treatment per 1000 gallons of water (20 to 200 parts per million of A24-4 Algae Treatment) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

FOR INDUSTRIAL USE ONLY

## Percent By Weight

Active Ingredient		
Poly [oxyethylene (dimethyliminio) ethylene	•	
(dimethyliminio) ethylene dichloride]	6	pct.
Inert Ingredient	94	pct.
Weight Per Gallon 8.43 pounds Weight of Active Ingredient 0.51 pounds		

## - CAUTION -Keep Out Of The Reach Of Children

Harmful if swallowed. Avoid contact with skin and eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists get medical attention. Avoid contamination of food.

This product is toxic to fish. Treated effluent should not be discharged into lakes, streams or public water. Do not contaminate water by cleaning of equipment or disposal of waste. Use only as directed on label.

Do not reuse small empty container, wash thoroughly with water and detergent. Discard in a safe place.

Do not reuse large empty drum. Destroy by perforating or crushing and burying in a safe place away from water supplies or return to drum reconditioner.