



SINCE 1904

WATER TREATMENT SPECIALISTS

ALGAE-SLIME TREATMENT

METLA-COTA 955

E.P.A. REG. NO. 13604-1

13604-1

Composition

	<u>Percent by Weight</u>
Active ingredient:	13.3 percent
Poly [oxyethylene (dimethyliminio) ethylene (dimethyliminio) ethylene dichloride].	13.3 percent
Inert ingredient:	86.7 percent
Weight per gallon:	8.55 pounds
Weight of active ingredient per gallon:	1.14 pounds

CAUTION

KEEP OUT OF THE REACH OF CHILDREN

Harmful if swallowed. Avoid contact with skin and eyes. In case of contact, flush with plenty of water for at least 15 minutes. If eye irritation persists, get medical attention. Avoid contamination of food.

Applications

Metla-Cota 955 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 4.55 to 11.38 fluid ounces of Metla-Cota 955 per 1,000 gallons, to provide a concentration of 37 to 92.5 parts per million of Metla-Cota 955 based on the total weight of water in the system is recommended. Repeat until control is achieved. Subsequent slug additions of 1.14 to 11.38 fluid ounces of Metla-Cota 955 per 1,000 gallons of water (9.25 to 92.5 parts per million of Metla-Cota 955) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleed-off and the severity of the microbiological problem. Slug additions should be made in the sump of the water cooling towers.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public waters. Do not contaminate water by cleaning of equipment or disposal of wastes. Use only as directed on label. Do not reuse container. Destroy when empty.

THE STATE MANUFACTURING COMPANY, INC., CLEVELAND, OHIO 44105