



SINCE 1904

WATER TREATMENT SPECIALISTS

ALGAE-SLIME TREATMENT

Water Treatment Microbiocide
For Building and Industrial
Recirculating Water Cooling Towers

METLA-COTA 954

E.P.A. REG. NO. 13604-2

ACCEPTED
July 22, 1974
UNDER THE FEDERAL INSECTICIDE
FUNGICIDE AND ROENTGENIC ACT
FOR ECONOMIC POISON REGISTERED
EPA REG. NO. 13604-2

FIRST AID

In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash contaminated clothing before re-use. If swallowed, drink promptly a large quantity of milk, egg whites, or gelatin solution, or if these are not readily available, drink large quantities of water. Avoid alcohol. Call a physician immediately!

NOTE TO PHYSICIAN

Probable mucosal damage may contraindicate the use of gastric lavage. Measures against circulatory shock, respiratory depression, and convulsions may be needed.

USED CONTAINER HANDLING AND DISPOSAL

1, 5, and 15 Gallon Drums: Rinse empty container thoroughly with water and discard it.
30 and 55 Gallon Drums: Do not re-use empty drum. Return drum to reconditioner or destroy it by perforating or crushing and burying in a safe place away from water supplies.

TWIN CHAIN QUATERNARY AMMONIUM COMPOUND CONCENTRATE

Active Ingredients:	
Didecyl dimethyl ammonium chloride	50%
Isopropyl alcohol	20%
Inert Ingredients:	30%
Total:	100%

Net Weight:	400 lbs.
Weight per Gallon:	7.49 lbs.
Net Volume:	55 gal.

DANGER

KEEP OUT OF REACH OF CHILDREN. SEE LEFT PANEL FOR ADDITIONAL PRECAUTIONARY STATEMENTS.

Corrosive. Causes severe skin and eye damage. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

USE DIRECTIONS

To control algae and bacterial slime use Metla-Cota 954 as directed. For best results apply (slug feed) at a point in the system where the product will be uniformly mixed. Begin treatment when the system is in jeopardy of becoming affected, or after cleaning systems whose efficiency is already impaired. Badly fouled systems must be cleaned before treatment is begun. Initially, use 6 fl. oz. per 1,000 gallons of water to be treated (20 ppm active quaternary). Repeat until control is achieved. Increase dosage to 9 fl. oz. if necessary per 1,000 gallons of water. When the above treatment level is successful, use 2-3 fl. oz. per 1,000 gallons of water weekly or as needed to maintain control.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, ponds, streams, or public waters. Apply this product only as specified on label.

THE STATE MANUFACTURING COMPANY, INC.

WATER TREATMENT SPECIALISTS

FOUNDED 1904

Office and Laboratories, 3545 East 76th Street, Cleveland, Ohio 44105 - 271-2240