



contained in the system every 7 days or sooner should visible growth appear. Apply at a point in the system where the product will be uniformly mixed.

Begin treatment when the system is in Jeonardy of becoming affected or after cleaning systems whose efficiency is already impaired.

For best results, clean heavily contaminated systems before treatment with this product. If soap or anionic detergent is used, rinse thoroughly before charging with Industrial Water Treatment.

Do not be alarmed with the sudden appearance of organic debris in the system during the first week of operation. This is normal and is a good indication that Industrial Water Treatment has effectively penetrated and dislodged dead organic material which tenaciously adheres to metal and wooden surfaces as living matter. This debris should be removed from the system to avoid clogging of screens and pipes.

### DIRECTIONS FOR USE

s. io

Initial Dose: 1-2 gallons Industrial Water Treatment to each 5,000 gallons of water contained in the system. Repeat until control is achieved.

Periodic Dose: When microbial control is evident, add 1-3 quarts Industrial Water Treatment to each 5,000 gallons of water

INDUSTRIAL WATER TREATMENT

Concentrated slimicide for Industrial re-circulating water cooling towers. Helps keep water systems clear and free of visible algae slimes. Inhibits the growth of bacteria.

**ACTIVE INGREDIENTS:** n-Alkyl (60% C14, 30% C16, 5% ( C<sub>10</sub> dimethyl benzyl ammoniun rides ..... n-Alkyi (68% C11, 32% C1.) d ethylbenzyl ammonium chloride INERT INGREDIENTS: .....

\_EPA Reg. NET WT:

# FORRER CHEMICAL


N57 W13400 Carmen Avenue Menomonee Falls, Wisconsin

# DANGER

Keep out of reach of children. See other warnings on right side panel.

### CAUTION

(Fish and/or Wildlife) This product is toxic to rish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water.



1

C12, 5% m chlo- limethyl	5%
	100%
No. 13	798-1

When Industrial Water Treatment is used as directed, it will aid in controlling and/or preventing the development of unsanitary slime conditions which are unsightly, produce foul odors and which are often the cause of equipment breakdown.

Industrial Water Treatment is compatible with virtually all corrosion inhibition additives, but should not be used in the presence of soap or other anionic detergents. Industrial Water Treatment at use dilution is non-corrosive to inanimate hard surfaces.

### DANGER

Keep Out of Reach of Children. Causes severe eye and skin damage. Do not get in eyes, on skin or on clothing. Wear goggles or face shield, and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

# **FIRST AID**

In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash all contaminated clothing before reuse. if swallowed, drink milk, egg whites, gelatin solution, or if these are not available, drink large quantities of water. Call a physician.

Rinse empty container thoroughly with water and discard.