

**PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND
DOMESTIC ANIMALS**

CAUTION

Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

ENVIRONMENTAL HAZARDS

This product is toxic to fish. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

STORAGE AND DISPOSAL

Do not contaminate water, food, or feed by storage or disposal.

STORAGE: Do not stack more than four drums high. Leaking or damaged drums should be placed in overpack drums for disposal. Spills should be absorbed in sawdust or sand and disposed of in a sanitary landfill. Keep container closed when not in use.

PESTICIDE DISPOSAL: Wastes resulting from the use of this product may be disposed of on site or at an approved waste disposal facility.

CONTAINER DISPOSAL:

PLASTIC: Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, by incineration, or, if allowed by state and local authorities, by burning. If burned, stay out of smoke.

METAL: Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill or by other procedures approved by state and local authorities.

PM 32 15300-1
**CHEMICAL
TREATMENT.
CL-2151**

ACCEPTED
JUN 20 1996

Under the Federal Insecticide, Fungicide, and Rodenticide Act, as amended, for the pesticide registered under EPA Reg. No. 15300-1

ACTIVE INGREDIENT:

Poly[oxyethylene (dimethyliminio) ethylene dichloride]..... 7.5%

INERT INGREDIENT 92.5%

TOTAL..... 100%

THIS PRODUCT CONTAINS 0.64 LB. OF ACTIVE INGREDIENT PER GALLON AND WEIGHS 8.4 LB. PER GALLON.

KEEP OUT OF REACH OF CHILDREN

CAUTION

FIRST AID: If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or, if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

See Side Panels For Additional Precautions

Manufactured by:

CHEMTREAT, INC.

10040 Lickinghole Road
Ashland, Virginia 23005

EPA REG. NO 15300-1

EPA EST. NO. 15300-VA-1

NET CONTENTS _____

10/1
DIRECTIONS FOR USE

GENERAL CLASSIFICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

CHEMICAL TREATMENT CL-2151 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 8.0 to 20.0 fluid ounces of **CHEMICAL TREATMENT CL-2151** per 1000 gallons of water to provide a concentration of 64 to 160 parts per million of **CHEMICAL TREATMENT CL-2151**, based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 2.0 to 20.0 fluid ounces of **CHEMICAL TREATMENT CL-2151** per 1000 gallons of water (16 to 160 parts per million of **CHEMICAL TREATMENT CL-2151**) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

CHEMICAL TREATMENT CL-2151 is used to control bacteria in industrial airwashing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 37.5 to 62.4 fluid ounces of **CHEMICAL TREATMENT CL-2151** per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 25.3 to 62.4 fluid ounces of **CHEMICAL TREATMENT CL-2151** per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problems. Slug additions may be made to the sump or to the water collection trays of the airwash system.