

CGS ALGAECIDE #1

NET CONTENTS 1 GALLON

ACTIVE INGREDIENT

Poly (oxyethylene (dimethyliminio) ethylene-
(dimethyliminio) ethylene dichloride)..... 10.0%

INERT INGREDIENT

..... 90.0%

This product contains 0.85 lb. of active ingredient per gallon and weighs 8.49 lb. per gallon.

**KEEP OUT OF REACH OF CHILDREN
CAUTION**

PRECAUTIONARY STATEMENTS

HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

FIRST AID: If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or, if these are not available, drink large quantities of water. Do not drink alcohol. Call a physician immediately.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Keep out of lakes, streams, or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds or public water. For guidance, contact the regional office of the Environmental Protection Agency.

DIRECTIONS FOR USE GENERAL CLASSIFICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

CGS ALGAECIDE #1 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algae growth, microbiological sludge, and other deposits. An initial slug dose of 0.15 to 0.32 fluid ounces of CGS ALGAECIDE #1 per 1,000 gallons of water to provide a concentration of 40 to 120 parts per million of CGS ALGAECIDE #1, based on the total weight of water in the system, is recommended. Repeat initial dose as soon as control is evident.

Subsequent: Slug additions of 0.15 to 0.32 fluid ounces of CGS ALGAECIDE #1 per 1,000 gallons of water (12 to 120 parts per million of CGS ALGAECIDE #1) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of sludge and the severity of the microbiological problem. Slug additions should be made in the bulk of water cooling towers.

CGS ALGAECIDE #1 is used to control bacteria in existing air-cooling systems that maintain effective heat exchanging components. Prior to its use, systems should be cleaned to remove bacterial sludge and other deposits. An initial slug dose of 0.15 to 0.32 fluid ounces of CGS ALGAECIDE #1 per 1,000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 0.15 to 0.32 fluid ounces of CGS ALGAECIDE #1 per 1,000 gallons of water should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of sludge and severity of the bacterial problem. Slug additions may be made to the pump or to the water control box of the air-cooling system.


STORAGE & DISPOSAL: Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal, or cleaning of equipment. Do not reuse empty container. Triple rinse for equivalent and dispose of container in an incinerator or in an approved landfill or bury in a safe place. Residue that cannot be used or reprocessed should be disposed of in a landfill approved for pesticides or buried in a safe place away from water supply. Open burning is prohibited.

Manufactured by
CGS Industries, Inc.

28 Wilton Street, Hyde Park, MA 02138

EPA REG. NO. 176973

EPA EST. NO. 17697 MA-1



22