

A C C LIQUID CHLORINATING CONCENTRATE **SOLUTION-L**

A SODIUM HYPOCHLORITE SOLUTION FOR SANITIZATION IN THE WATER TREATMENT INDUSTRIES, LAUNDRY, ALGAE CONTROL IN SWIMMING POOLS, WATER TREATMENT. PUBLIC WATER SUPPLIES, AND WASTE WATER SYSTEMS.

> ACTIVE NGREDIENT: Socium Hypochlorite OTHER INGREDIENTS:

> > Hypothicite Soution 8 Company Material UNITO: FR

KEEP OUT OF REACH OF CHILDREN

DANGER

FIRST AID STATEMENT

IF IN EYES: Hodes, a open and rinsels of

contact anses if crasent after do sor contro denter or costo if further treatment accide

IF ON SKIN OR Take off contaminated distring CLOTHING: Times Calco son contro de

IF SWALLOWED: Oa alcoach contro center or box

so by do son control center ar ab-

IF INHALED:

altific a respiration preferably co or soctor for further treatment au 33.

Transport upright, never in passenger area. Protect rugs or upholstery. (See Side Panel for Additional Precautionary Statements)

algently with lister for 16 - 20 minutes. Remove first 5 minutes then continue rins no elle. Cal

inselskin immediatel, it thip enty of water for 15 - 20 for doctor for further treatment abli ce

mmediata , for further treatment advice imave dersor is dialglass of water if aciento i vallow. Doinot induce library unless to ditalet for Doinotigille anything by mouth to an unconscibus

Colle derson to fresh air i fice iith is not preaming ide. 911 champulance then que cuth-to-mourn (cossicie) Caliado son contro centar

HOT LINE NUMBER: Hallethe product container or actifivith you when balling a colson center or doctor longoing for treatment. Contact 1-800-221 il 222 for emergend, medical treatment information

NOTE TO PHYSICIAN. Probable mucosal damage imay contraind date the use of gastrol avage.

CONTENTS:

☐ BULK GAL.

55 GAL

15 GAL.

5 GAL.

DIRECTIONS FOR USE:

IT IS A VIOLATION OF FEDERAL LAW TO USE THIS PRODUCT IN A MANNER INCONSISTENT WITH ITS LABELING

Note: This product degrades with age. Use a chlorine test kit and increase dosage as necessary to obtain the required level of available chlorine.

STORAGE AND DISPOSAL:

Store in a cool, dry area, and away from direct sunlight or heat to avoid detenoration. In case of spill, flood areas with large quantities of water. Product or rinsates that cannot be used should be diluted with water before disposal in a sanitary sewer. Do not reuse empty container but return to ACCO or place in trash collection. Do not contaminate food or feed by storage, disposal, or cleaning of equipment

SWIMMING POOL WATER DISINFECTION: For a new pool or spring start-up, superchlorinate to yield 5 to 10 ppm available chlorine by weight. Check the level of available chlorine with a test kit Adjust and maintain pool water oH to between 7.2 and 7.6. Adjust and maintain the alkalinity of the pool to between 50 to 100 ppm. (See Table of Proportions.) To maintain the pool, add manually or by a feeder device to yield an available chlorine residual between 0.6 to 1.0 ppm by weight. Stabilized pools should maintain a residual of 1.0 to 1.5 ppm available chlorine. Test the pH, available chlorine residual, and alkalinity of the water frequently with appropriate test kits. Frequency of water treatment will depend upon temperature and number of swimmers. (See Table of Proportions.) Every 7 days, or as necessary, superchlorinate the pool to yield 5 to 10 ppm. available chlorine by weight. Check the level of available chlorine with a test kit. Do not reenter gool until the chlorine residual is between 1 0 to 4 0 ppm. (See Table of Proportions.) Re-entry into treated pools is prohibited above levels of 4 ppm due to risk of bodily harm. At the end of the swimming pool season or when water is to be drained from the pool, chloring must be allowed to dissipate from treated pool water before discharge. Do not chlorinate the pool within 24 hours prior to discharge.

WINTERIZING POOLS: While water is still clear & clean, obtain while filter is running a 3 ppm available chlorine residual, as determined by a suitable test kit. Cover pool, prepare heater, filter, and heater components for winter by following manufacturer's instructions (See Table of Proportions) SPAS/HOT-TUBS: See Table of Proportions to obtain a free available chlorine concentration of 5 ppm, as determined by a suitable chlorine test kit. Adjust and maintain pool water pH to between 7.2 and 7.8. Some oils, lotions, fragrances, cleaners, etc., may cause foaming or cloudy water as well as the efficiency of the product. To maintain the water, see Table of Proportions to maintain a chlorine concentration of 5 ppm. After each use, see Table of Proportions and apply product to raise to 16 ppm available chlorine to control odor and algae. Do not enter spa or tub until chlorine concentration is back to 5 ppm. Re-entry into treated pools is prohibited above levels of 5 ppm. due to risk of bodily harm. During extended periods of disuse, see Table of Proportions and add product to maintain a 3 port chlorine concentration

DISINFECTION OF DRINKING WATER (PUBLIC SYSTEMS): (See Table of Proportions.) Prepare a 10 ppm solution. Begin feeding this solution with a hypochlorinator until a free available chlorine residual of at least 0.2 ppm and no more than 0.6 ppm is attained throughout the distribution system. Check water frequently with a chlorine test kit. Bacteriological sampling must be conducted at a frequency no less than that prescribed by the National Primary Drinking Water Regulations Contact your local health department for further details.

DISINFECTION OF DRINKING WATER (EMERGENCY DISINFECTION): When boiling water for 1 minute is not practical, water can be made potable by using this product. Prior to addition of the sanitizer, remove all suspended material by filtration or by allowing it to settle to the bottom Decant the clarified, contaminated water to a clean container. Then add this product to make a 0.6 ppm solution (See Table of Proportions.) Allow the treated water to stand for 30 minutes. Properly treated water should have a slight chlorine odor. If not, repeat dosage and allow the water to stand an additional 15 minutes. The treated water can then be made palatable by pouring it between clean containers for several times.

JAN 12 2007

Under the Federal Insectified, Functions, and Rodemicide, Act as amanded, for the pesticide, registered linger LEPA Reg. No. 136 EPA Reg. No. 79

PUBLIC WATER SYSTEMS: See Instruction Sheet SEWAGE & WASTEWATER EFFLUENT TREATMENT. See Instruction Sheet SEWAGE & WASTEWATER TREATMENT: See Instruction Sheet. LAUNDRY SANITIZERS: See Instruction Sheet. SANITIZATION OF MONPOROUS FOOD CONTACT SURFACES. See Instruction Sheet

TABLE OF PROPORTIONS - ACCO Liquid Chlorinating Concentrate Solution-L

100 ppm - 89 fluid ounces per 1,000 gallons water 200 ppm - 1 fluid ounce per 5 gallons water 800 ppm - 4 fluid ounces per 5 gallons water 1,000 ppm - 5 fluid ounces per 5 gallons water Do not apply this product through any type of irrigation system.

PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS:

DANGER: CORROSIVE:

May cause severe skin and eye irritation or chemical burns to broken skin. Causes eye damage. Wearsafety glasses or goggles and rubbergloves when handling this product. Washafter handling. Avoid breathing vapors. Vacate poorly ventilated areas as soon as possible. Do not return until odors-

PHYSICAL OR CHEMICAL HAZARDS: STRONG OXIDIZING AGENT:

Mix only with water according to label directions. Mixing this product with chemicals (e.g. ammonia, acids, detergents, etc.) or organic matter (e.g. urine, feces, etc.) will release chlorine gas which is imitating to eyes, lungs, and mucous membranes.

ENVIRONMENTAL HAZARDS:

This product is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans, or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance, contact your State Water Board or Regional Office of the EPA.

NFPA SYMBOL

EPA REG. NO.: 19369-4 EPA EST. NO.: 19369-IA-001



NSF 60

STATE AND LOCAL REGULATIONS: Consult your dealer, state, or local health authorities for additional information.

ACCO Unlimited Corporation makes no warranty, expressed or implied, concerning this material, except that it conforms to the chemical description on this label. Neither ACCO Unlimited Corporation nor seller shall be held responsible in any manner for personal injury or property damage, or other type of loss resulting from handling, storage or use of this material. The buyer assumes all risk and liability therefrom and accepts and uses this material on these conditions

MANUFACTURED BY:



LAUNDRY SANITIZERS

Household Laundry Sanitizers: IN SOAKING SUDS: See Table of Proportions and provide 200 ppm allable chlorine solution. Wait 5 minutes, then add soap or detergent. Immerse laundry for at least 11 minutes prior to inting the wash/rinse cycle. IN WASHING SUDS: See Table of Proportions and add sufficient product to wash water containing clothes to provide 200 ppm available chlorine. Wait 5 minutes, then add soap or detergent and start the wash/nnse cycle.

Commercial Laundry Sanitizers: Wet fabrics or clothes should be spun dry prior to sanitization. Thoroughly mix sufficient proportion of this product with 10 gallons of water to yield 200 ppm available chlorine. (See Table of Proportions.) Promptly after mixing the sanitizer, add the solution into the pre-wash prior to washing fabrics/clothes in the regular wash cycle with a good detergent. Test the level of available chlorine, if solution has been allowed to stand. Add more of this product if the available chlorine level has dropped below 200 ppm.

SANITIZATION OF NONPOROUS FOOD CONTACT SURFACES

Rinse Method: A solution of 100 ppm available chlorine may be used in the sanitizing solution if a chlorine test kit is available. Solutions containing an initial concentration of 100 ppm available chlorine must be tested and adjusted periodically to ensure that the available chlorine does not dorp below 50 ppm. See Table of Proportions and prepare a 100 ppm solution. If no test kit is available, see Table of Proportions and prepare a sanitizing solution to provide approximately 200 ppm available chlorine by weight.

Clean equipment surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the sanitizing solution, maintaining contact with the sanitizer for at least 2 minutes. If solution contains less than 50 ppm available chlorine, as determined by the suitable test kit, either discard the solution or add sufficient product to me-establish a 200 ppm residual. Do not rinse equipment with water after treatment and do not soak equipment oversight.

Sanituzers used in automated systems may be used for general cleaning but may not be re-used for sanitizing purposes

Immersion Method: A solution of 100 ppm available chlorine (See Table of Proportions) may be used in the sanitzing solution if a chlorine test kit is available. (See Table of Proportions.) Solutions containing an initial concentration of 100 ppm available chlorine must be tested and adjusted periodically to ensure the available chlorine does not drop below 50 ppm. See Table of Proportions and prepare a 100 ppm sanitizing solution. If no test kit is available, see Table of Proportions and prepare 200 ppm available chlorine by weight.

Clean equipment in the normal manner. Prior to use, immerse equipment in the sanitizing solution for at least 2 minutes and allow the sanitizer to drain. If solution contains less than 50 ppm available chlorine, as determined by a suitable test kit, either discard the solution or add sufficient product to re-establish a 200 ppm residual. Do not rinse equipment with water after treatment.

Sanitizers used in automated systems may be used for general cleaning but may not be re-used for sanitizing purposes

Flow/Pressure Method: Disassemble equipment and thoroughly clean after use. Assemble equipment in operating position prior to use. Prepare a volume of a 200 ppm available chlorine sanitizing solution equal to 110% of volume capacity of the equipment. (See Table of Proportions.) Pump solution through the system until full flow is obtained at all extremities, the system is completely filled with the sanitizer, and all air is removed from the system. Close drain valves and hold under pressure for at least 2 minutes to ensure contact with all internal surfaces. Remove some cleaning solution from drain valve and test with a chlorine test kit. Repeat entire cleaning/sanitizing process if effluent contains less than 50 ppm available chlorine.

Clean-In-Place Method: Thoroughly clean equipment after use. See Table of Proportions to prepare a volume of a 200 ppm available chlorine sanitizing solution equal to 110% of volume capacity of the equipment. Pump solution through the system until full flow is obtained at all extremities, the system is completely filled with the sanitizer, and all air is removed from the system. Close drain valves and hold under pressure for at least 10 minutes to ensure contact will all internal surfaces. Remove some cleaning solution from drain valve and test with a chlorine test kit. Repeat entire cleaning/sanitizing process if effluent contains less than 50 ppm available chlorine.

Spray/Fog Method: Preclean all surfaces after use. Use a 200 ppm available chlorine solution to control bacteria, mold, or fungi and a 600 ppm solution to control bacteriophage. Use spray or fogging equipment which can resist hypochlorite solutions. Always empty and rinse sprayfog equipment with potable water after use. Thoroughly spray or fog all surfaces until wet, allowing excess sanitizer to drain. Vacate area for at least 2 hours. Prior to using equipment, rinse all surfaces treated with a 600 ppm solution with a 200 ppm solution. (See Table of Proportions.)

PUBLIC WATER SYSTEMS

Reservoirs - Algae Control: Hypochlonnate streams feeding the reservoir. Suitable feeding points should be selected on each stream at least 50 vards upstream from the points of entry into the reservoir.

Main: Thoroughly flush section to be sanitized by discharging from hydrants. Permit a water flow of at least 2.5 feet per minute to continue under pressure while injecting this product by means of a hypochlorinator. Stop water flow when a chlorine residual test of 50 ppm is obtained at the low pressure end of the new main section after a 24 hour retention time. When chlorination is completed, the system must be flushed free of all heavily chlorinated water.

New Tanks, Basins, Etc.: Remove all physical soil from surfaces. Use a 500 ppm available chlorine solution. (See Table of Proportions.) Filt to working capacity and allow to stand for at least 4 hours. Drain and flush with potable water and return to surface.

New Filter Sand: Apply 80 oz. of this product for each 150 to 200 cubic feet of sand. The action of the product dissolving as the water passes through the bed will aid in sanitizing the new sand.

New Wells: Flush the casing with a 50 ppm available chlonne solution of water. (See Table of Proportions.) The solution should be pumped or fed by gravity into the well after thorough mixing with agitation. The well should stand for several hours or overnight under chlorination. It may then be pumped until a representative raw water sample is obtained. Bacterial examination of the water will indicate whether further treatment is necessary.

Existing Equipment: Remove equipment from service, thoroughly clean surfaces of all physical soil. Sanitize by using a solution of approximately 500 ppm available chlonne. (See Table of Proportions.) Fill to working capacity and let stand for at least 4 hours. Drain and place in service. If the previous treatment is not practical, surfaces may be sprayed with a solution containing approximately 1,000 ppm available chlorine. After drying, flush with water and return to service.

SEWAGE & WASTEWATER EFFLUENT TREATMENT

The disinfection of sewage effluent must be evaluated by determining the total number of coliform bacteria and/or fecal coliform bacteria, as determined by the Most Probable Number (MPN) procedure, of the chlorinated effluent has been reduced to or below the maximum permitted by the controlling regulatory jurisdiction.

On the average, satisfactory disinfection of secondary wastewater effluent can be obtained when the chionne residual is 0.5 ppm after 15 minutes contact. Although the chlorine residual is the critical factor in disinfection, the importance of correlating chlorine residual with bacterial kill must be emphasized. The MPN of the effluent, which is directly related to the water quality standards requirements, should be the final and primary standards and the chlorine residual should be considered an operating standard valid only to the extent verified by the coliform quality of the effluent.

The following are critical factors affecting wastewater disinfection:

- 1 Moung. It is imperative that the product and the wastewater be instantaneously and completely flash mixed to assure reaction with every chemically active soluble and particulate component of the wastewater.
- 2. Contacting: Upon flash mixing, the flow through the system must be maintained.
- Dosage/Residual Control: Successful disinfection is extremely dependent on response to fluctuating chlorine demand to maintain a predetermined, desirable chlorine level. Secondary effluent should contain 0.2 to 1 0 ppm chlorine residual after a 15 to 30 minute contact time. A reasonable average of residual chlorine is 0.5 ppm after 15 minutes contact time.

SEWAGE AND WASTEWATER TREATMENT

Effluent Slime Control: Apply a 100 to 1000 ppm available chlorine solution at a location which will allow complete mixing. Once control is evident, apply a 15 ppm available chlorine solution. (See Table of Proportions.)

Filter Beds Stime Control: Remove filter from service. Drain to a depth of 1 ft. above filter sand, and add product to obtain 500 ppm evenly over the surface. (See Table of Proportions.) Wait 30 minutes before draining water to a level that is even with the top of the filter. Wait for 4 to 6 hours before completely draining and backwashing filter.

10/06 jp



