POOL CLEAR

DISINFECTANT AND GERMICIDE
FOR: SWIMMING POOL WATER TREATMENT
CONTENTS 1 GALLON NET

POOL

SWIMMING POOL CHEMICALS

WARNING KEEP OUT OF REACH OF CHILDREN

ACTIVE INGREDIENT - SODIUM HYPROCHLORITE 12.5% BY WEIGHT

INERT INGREDIENTS - 87.5 % BY WEIGHT

POOL PRIDE CHEMICALS

DISTRIBUTED BY CENTRAL POOL SUPPLY, INC. MOLINE, IL. PEORIA, IL GRIMES, IA

EPA REG. NO. 27029-1

SEE BACK PANEL FOR OTHER PRECAUTIONS AND FIRST AID.

WARNING

KEEP OUT OF REACH OF CHILDREN, HARMFUL IF SWALLOWED, STRONG OXIDANT, MAY PRODUCE CHEMICAL BURNS, DO NOT GET ON SKIN OR IN EYES. IN CASE OF CONTACT WITH SKIN AND EYES, FLUSH WITH PLENTY OF WATER. IF SKIN IRRITATION PERSISTS, GET MEDICAL ATTENTION. FOR EYES, GET PROMPT MEDICAL ATTENTION

FIRST AID - EXTERNAL - FLUSH WITH PLENTY OF WATER GET

INTERNAL DOWN ME DOWN AND AND AND AND MORE OF HILL OF WATER A A ATTEMPT AT PHILE

ORDED : CHOINE STERMING FOR ECONOMIC PULLAN REGISTER-

WARNING KEEP OUT OF REACH OF CHILDREN

ACTIVE INGREDIENT - SODIUM HYPROCHLORITE 12.5% BY WEIGHT

INERT INGREDIENTS - 87.5 % BY WEIGHT

POOL PRIDE CHEMICALS

DISTRIBUTED BY, CENTRAL POOL SUPPLY, INC. MOLINE, IL. PEORIA, IL. GRIMES, IA.

EPA REG. NO. 27029-1

SEE BACK PANEL FOR OTHER PRECAUTIONS AND FIRST AID.

WARNING

KEEP OUT OF REACH OF CHILDREN, HARMFUL IF SWALLOWED, STRONG OXIDANT, MAY PRODUCE CHEMICAL BURNS, DO NOT GET ON SKIN OR IN EYES. IN CASE OF CONTACT WITH SKIN AND EYES, FLUSH WITH PLENTY OF WATER. IF SKIN IRRITATION PERSISTS, GET MEDICAL ATTENTION. FOR EYES, GET PROMPT MEDICAL ATTENTION.

FIRST AID - EXTERNAL - FLUSH WITH PLENTY OF WATER, GET PROMPT MEDICAL ATTENTION.

INTERNAL - DRINK MUCILAGE, RAW EGG WHITE, MILK OR RICE GRUEL. FOLLOW WITH TABLESPOON OF MUSTARD IN GLASS OF WATER, CALL A PHYSICIAN. RINSE EMPTY CONTAINER THOROUGHLY WITH WATER AND DISCARD IT, OR RETURN IT TO CENTRAL POOL SUPPLY, INC.

STORAGE - STORE IN A COOL DARK PLACE. DEGRADES WITH AGE. USE A TEST KIT AND INCREASE DOSAGE AS NECESSARY TO OBTAIN REQUIRED LEVEL OF AVAILABLE CHLORINE.

FOR USE IN:

SWIMMING POOLS - FOR NEWLY FILLED POOLS -

TO ESTABLISH A CHLORINE RESIDUAL TO DISENFECT THE POOL; ADD 1/2 GALLON OF PRODUCT FOR EACH 15,000 GALLONS OF WATER, REPEAT THE DOSAGE UNTIL A CHLORINE RESIDUAL OF 0,6 TO 1.0 PPM IS ESTABLISHED.

FOR DAILY POOL MAINTENANCE -

ADD 1 QUARTAFOR EACH 15,000 GALLONS OF WATER DAILY OR AS NEEDED TO MAINTAIN A CHLORINE RESIDUAL OF 0.6 TO 1.0 PPM TEST POOL WATER FREQUENTLY WITH A CHLORINE TEST KIT TO MAINTAIN THE DESIRED CHLORINE RESIDUAL. THE POOL WATER SHOULD BE MAINTAINED AT A PH OF 7.2 TO 7.6 AS DETERMINED BY A TEST KIT.

MOLINE IL PEDRIA IL GRIMES IA