

COOLING TOWER ALGAECIDE, FUNGICIDE

ACTIVE INGREDIEN1 12.0 PERCENT Poly [oxyethylene (dimethyliminio) ethylene (dimethyliminio) ethylene dichtoride}

INERT INGREDIENT

100 0 PERCENT

88 0 PERCENT

THIS PRODUCT CONTAINS 1 02 LBS OF ACTIVE INGREDIENT PER GALLON AND WEIGHS8 53 LB PER GALLON

KEEP OUT OF REACH OF CHILDREN CAUTION

PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS.

CAUTION: Harmful is swallowed. Avoid breathing vapors. Avoid contact with skin, eyes or clothing.

PRACTICAL TREATMENT (FIRST AID): If swallowed, promptly drink a large quantity of milk, egg white, gelatin solution or if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Keep out of lakes, streams or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds or public water. For guidance, contact the regional office of the Environemntal Protection Agency

PRODUCT CODE 1023

-14

-;

BEST DOCUMENT AVAILABLE

DIRECTIONS FOR USE GENERAL CLASSIFICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling

A & S 100 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth microbiological slime and other deposits.

An initial slug addition of 5.0 to 12.5 fluid ounces of A & S 100 per 1000 gallons of water to provide a concentration of 40 to 100 parts per million of A & S 100, based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 1.20 to 12.5 fluid ounces of A & S 100 per 1000 gallons of water (10 to 100 parts per million A & S 100) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

STORAGE AND DISPOSAL

Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal, or cleaning of equipment. The container must be triple rinsed (or equivalent) and offered for recycling, reconditioning, or disposal in an approved landfill or buried in a safe place. Rinsate that cannot be used or reprocessed should be disposed of in a landfill approved for pesticides or buried in a safe place away from water supplies. Open dumping is prohibited.

EPA EST 28070-Fi-1

MANUFACTURED BY Clarke Chemical Corporation P.O. Box 332 Miami, Florida 33147 EPA REG 28070-2

 $\leq H$

NET CONTENTS:

30 Gallons