

CHLORINE



DANGER - POISON

ACTIVE INGREDIENT:
CHLORINE 100%

NET CONTENTS 150 POUNDS

EPA Reg. No. 29443-1

KEEP OUT OF REACH OF CHILDREN
NONFLAMMABLE LIQUID AND GAS UNDER PRESSURE

Do not heat container

Do not breathe air containing this gas

Do not get in eyes or on skin

Have available gas masks approved for chlorine service by the U.S. Bureau of Mines or the National Institute for Occupational Safety and Health. Handle and use only in accordance with practice recommended in the CHLORINE MANUAL published by The Chlorine Institute, Inc. N.Y. IN CASE OF EXPOSURE, move patient to fresh air, Keep him warm and quiet. Call a physician.

Distributed By: TREATRITE WATER LABS. INC.

1602 EAST STREET — IOLA, KANSAS 66749

"The valve outlet on this container complies with American National Standard B57.1. To connect the discharge line, unscrew valve outlet cap and attach yoke and adapter or special union connector. Do not use pipe fittings. Use new gasket each time connection is made.

Open valve by turning to left (counter clockwise) one complete turn, using 3/8" square box wrench. Special wrench can be purchased from us.

Packing nut may be slightly loosened if necessary to relieve tight valve: retighten promptly to avoid leak. Do not overtighten.

Before using ton containers place them so valves are in a vertical line. Top valve will deliver gas and bottom valve will deliver liquid.

When container is empty, close valves securely, replace valve outlet caps and replace valve protection hood.

