



Phone 605/336-6710

P.O. Box 408

Sioux Falls, So. Dak. 57101

A-160

LOW FOAM WATER TREATMENT MICROBIOCIDES FOR BUILDING AND INDUSTRIAL RECIRCULATING COOLING TOWERS

COMPOSITION

Ingredients	
dimethyl ammonium chloride	
alcohol	
Ingredients	
Weight per gallon	7.98 lb.
Weight of active ingredients per gallon	3.99 lb.

Percent by Weight

- 50 percent
- 10 percent
- 40 percent

ACCEPTED
 BY THE FEDERAL INSTITUTE OF
 FUNGICIDE AND RODENTICIDE CONTROL
 FOR ECONOMIC POISON REGISTRATION
 REG. UNDER NO. 11657-1

APPLICATIONS

Control of algae in recirculating commercial and industrial cooling water systems. Before treatment with Walling A-160 systems must be cleaned to remove algal growth. Then the system should be treated with an initial slug addition of 16 to 21 fluid ounces of Walling A-160 per 1,000 gallons of water in the system. Repeat the initial treatment slug additions of 6 to 9 fluid ounces of Walling A-160 per 1,000 gallons of water should be made every 1 to 5 days or as needed. The required frequency of treatment depends on the severity of the microbiological problem. Slug additions of Walling A-160 should be made to the sump of water cooling towers.

DANGER — KEEP OUT OF REACH OF CHILDREN

Irritative. Causes severe eye and skin damage. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if inhaled. Do not use, pour, spill or store near heat or open flame.

Immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash contaminated clothing before reuse. In case of ingestion, drink large quantities of water. Avoid alcohol. Call a physician immediately. Gastric damage may contraindicate the use of gastric lavage. Measures against circulatory shock, respiratory depression and convulsion may be needed.

Do not reuse drum conditioner or destroy by perforating or crushing and burying in a safe place.

Effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Do not contaminate water by cleaning of equipment, or disposal of wastes. See instructions on this label.

EPA Est. No. 11659-SD-1