

M-2010

JUL 30 1973
UNDER THE FEDERAL INSECTICIDE
FUNGICIDE AND RODENTICIDE ACT
FOR ECONOMIC POISON REGISTER-
ED UNDER NO. SUBJECT
TO ATTACHED COMMENTS.

Active ingredient..... 10.0 Percent
Poly[oxyethylene(dimethyliminio)ethylene(dimethyliminio)-
ethylene dichloride].....10.0 percent
Inert ingredient..... 90.0 Percent
Weight per gallon..... 8.49 pounds
Weight of active ingredient per gallon 0.85 pound

Application: M-2010 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 6.13 to 15.32 fluid ounces of M-2010 per 1,000 gallons of water to provide a concentration of 48 to 120 parts per million of M-2010 based on the total weight of water in the system is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 1.53 to 15.32 fluid ounces of M-2010 per 1,000 gallons of water (12 to 120 parts per million of M-2020) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

CAUTION: KEEP OUT OF REACH OF CHILDREN - Harmful if swallowed. Do not get in eyes. Avoid contact with skin. In case of contact, flush with plenty of water for at least 15 minutes. If eye irritation persists, get medical attention. Avoid contamination of food.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Do not contaminate water by cleaning of equipment or disposal of wastes. Use only as directed on label. Do not reuse empty drum. Return to drum reconditioner or destroy by perforating or crushing and burying in a safe place away from water supplies.

EPA reg. #33368-4

CULLIGAN INDUSTRIAL WATER TREATMENT DIV.
CULLIGAN WATER CONDITIONING, INC.
1242 MARKET STREET
CHATTANOOGA, TENNESSEE 37402
PHONE: 267-4326