

OLIN Water Treatment Products

S-522 L

CHEMICAL FORMULATION
for cleaning bacterial slime
clogged fan coil drains



CAUTION: KEEP OUT OF THE REACH OF CHILDREN.

Harmful if swallowed. Irritating to skin and eyes. Do not get in eyes or on skin. In case of contact with skin or eyes, flush with plenty of water. If irritation persists, get medical attention.


Rinse Empty Container Thoroughly with water and discard it.

ACTIVE INGREDIENTS:

n-Alkyl (60% C₁₄, 30% C₁₆, 5% C₁₂, 5% C₁₈)
dimethyl benzyl ammonium chlorides

n-Alkyl (50% C₁₂, 30% C₁₄, 17% C₁₆, 3% C₁₈)
dimethyl ethylbenzyl ammonium chlorides

INERT INGREDIENTS:



INSTRUCTIONS FOR USE TO CLEAN A BACTERIAL SLIME CLOGGED FAN COIL DRAIN WITH S 522 L.

1. If possible, turn water on and add S 522 L.
2. Allow 10 to 15 minutes for S 522 L to act. The pipe drain should clear within several minutes.
3. If drain does not partially clear, rinse with water. If this does not clear pipe drain, repeat steps 1 and 2.
4. If pipe drain still does not clear, use S 522 L on a brush or sponge.
5. To avoid further clogging, use the clean drain pan of PA Reg. No. 1200 249 immediately after use.

EPA Reg. No. 1200 249

S-522 L 77

olin WATER SERVICE LABORATORIES

OLIN CORPORATION, 120 LONG RIDGE ROAD, STAMFORD, CONN. 06904