



# OLIN 3200

For industrial cooling water treatment

EPA Est. No.  
33576-CA-1  
33576-KS-1  
33576-NY-1

Open recirculating water cooling tower and evaporative condenser systems. To control bacterial and fungal slime:

1. Begin treatment when the system is in jeopardy of becoming affected or after cleaning systems whose efficiency is already impaired. Thoroughly clean systems fouled with slime and scale.
2. **Initial dose**—5.5-10.5 fl. oz. OLIN 3200 per 1,000 gal. water (40-80 ppm) applied directly to the cooling tower basin near the inlet to the recirculating pump. Repeat until control is achieved.
3. **Subsequent dose**—1.5-4.0 fl. oz. OLIN 3200 per 1,000 gal. water (10-30 ppm) applied every 7 days or as needed to maintain control.

OLIN 3200 is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Apply this product only as specified on this label.

**ACTIVE INGREDIENTS:**

n-Alkyl (60% C <sub>11</sub> , 30% C <sub>16</sub> , 5% C <sub>12</sub> , 5% C <sub>14</sub> ) dimethyl benzyl ammonium chlorides	25%
n-Alkyl (50% C <sub>12</sub> , 30% C <sub>14</sub> , 17% C <sub>16</sub> , 3% C <sub>14</sub> ) dimethyl ethylbenzyl ammonium chlorides	25%
INERT INGREDIENTS:	50%
	100%

**DANGER**  
Keep Out of Reach of Children

Corrosive. Causes severe eye and skin damage. Do not get in eyes, on skin or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food. Rinse empty container thoroughly with water and discard it.

**FIRST AID:** In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash contaminated clothing before reuse. If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution or if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

**NOTE TO PHYSICIAN:** Probably mucosal damage may contraindicate the use of gastric lavage. Measures against circulatory shock as well as oxygen and measures to support breathing manually or mechanically may be needed. If persistent, convulsions may be controlled by the cautious intravenous injection of a short-acting barbiturate drug.

EPA REG. NO. 33576-4-AA-50607

FOR INDUSTRIAL USE ONLY

lb. Net Wt.

**Olin WATER SERVICES**

**Kansas City, Kansas 66115**

Olin Corporation

Stamford, Conn. 06904